

RETURN TO STUDENT

# **WATER SUPPLY STUDY**

## **PULLMAN-MOSCOW WATER RESOURCES COMMITTEE**

**City of Moscow  
City of Pullman**

**University of Idaho  
Washington State University**



**Stevens, Thompson & Runyan, Inc.**  
*Engineers / Planners*  
PORTLAND • SEATTLE • BOISE • ANCHORAGE



**Stevens, Thompson & Runyan, Inc.**

*Engineers / Planners*

827 LA CASSIA DRIVE

BOISE, IDAHO 83705

TELEPHONE (208) 343-3609

Fifty Years  
1920-1970

Portland  
Seattle  
Boise  
Anchorage

B-100.001

August 1, 1970

LETTER OF TRANSMITTAL

Pullman-Moscow Water Resources Committee  
John F. Orsborn, Chairman  
Albrook Hydraulic Laboratory  
Washington State University  
Pullman, Washington 99163

Gentlemen:

Pursuant to your instructions and our agreement of December, 1969, we have completed the engineering studies, including review of potential surface water sources, necessary for selection of a development plan for the Pullman-Moscow Area. Our report of these studies including findings and recommendations is herewith presented.


As set forth in the report, the development of a new water supply system calls for a complete readjustment in the present usage of ground water. Our recommendations propose two alternates: one, the Palouse River with storage at Laird and two, the Snake River at Wawawai. We believe the latter to be the most practical. Annual costs of facilities called for in development of the Snake River project are estimated at \$1,000,000 and, depending on federal participation in first stage capital costs, substantial local revenue will be required. However, we are firmly convinced that the system is eligible for federal financial assistance and every effort should be made to maximize such assistance.

A major advantage of the Snake River project, in addition to lowest first cost, is its amenability to early completion when compared to the Palouse plan.

We appreciate having the opportunity to again be of service to your communities and look forward to working with you in accomplishing the objectives you have set.

Respectfully submitted,

STEVENS, THOMPSON & RUNYAN, INC.

  
By: James A. Crom  
Vice President

JAC:dkf

WATER SUPPLY STUDY

A REPORT

PREPARED FOR THE

PULLMAN-MOSCOW WATER RESOURCES  
COMMITTEE

ON THE STUDY OF FUTURE WATER SUPPLIES  
FOR THE PULLMAN-MOSCOW AREA

AUGUST, 1970

STEVENS, THOMPSON & RUNYAN, INC.  
Engineers / Planners  
Portland Seattle Boise Anchorage

## TABLE OF CONTENTS

|     |  | <u>Page</u> |
|-----|--|-------------|
| I   | INTRODUCTION                                 | I- 1        |
|     | Study Authorization                          | I- 1        |
|     | Scope  | I- 1        |
|     | Objectives                                   | I- 2        |
|     | Study Development                            | I- 3        |
|     | Area to be Served                            | I- 3        |
|     | Information and Data Available               | I- 4        |
|     | Nomenclature                                 | I- 5        |
| II  | POPULATION GROWTH AND<br>FUTURE WATER DEMAND | II- 1       |
|     | General                                      | II- 1       |
|     | Available Data                               | II- 1       |
|     | P-MWRC Projections                           | II- 2       |
|     | Preparation of Area Projections              | II- 3       |
|     | Projected Water Demand                       | II- 9       |
|     | Conclusions                                  | II-11       |
| III | WATER SUPPLY SOURCES                         | III- 1      |
|     | General                                      | III- 1      |
|     | Available Sources                            | III- 1      |
|     | Water Quality                                | III- 4      |
|     | Environmental Considerations                 | III- 8      |
|     | Effects on Ecological Systems                | III- 9      |
|     | Effects on Inhabitants                       | III-10      |
| IV  | PREVIOUS STUDIES                             | IV- 1       |
|     | General                                      | IV- 1       |
|     | Bureau of Reclamation Study                  | IV- 1       |
|     | Sutherland Study                             | IV- 2       |
|     | Corps of Engineers Palouse Basin Studies     | IV- 3       |

|     |   |        |
|-----|---|--------|
| V   | REVIEW OF CORPS OF ENGINEERS<br>PROJECT | V- 1   |
|     | General                                 | V- 1   |
|     | Pumping and Transmission Facilities     | V- 2   |
|     | Effect of Regulated Release             | V- 4   |
|     | Conclusions                             | V- 4   |
| VI  | ALTERNATE COMPARISON CRITERIA           | VI- 1  |
|     | General                                 | VI- 1  |
|     | Flow Requirements                       | VI- 1  |
|     | Conjunctive Use Plan                    | VI- 2  |
|     | Flow Criteria                           | VI- 4  |
|     | Pipelines                               | VI- 4  |
|     | Terminal Storage                        | VI- 5  |
|     | Pumping Plant                           | VI- 5  |
|     | Storage Reservoir                       | VI- 6  |
|     | Water Treatment                         | VI- 6  |
|     | Power                                   | VI- 8  |
|     | Economic Comparison                     | VI- 9  |
| VII | ALTERNATIVE PLANS OF<br>WATER SUPPLY    | VII- 1 |
|     | General                                 | VII- 1 |
|     | Snake River Project                     | VII- 4 |
|     | Palouse River Basin Project             | VII- 8 |
|     | Troy Watershed Project                  | VII-12 |
|     | Potlatch River Project                  | VII-18 |
|     | Clearwater River Project                | VII-21 |
|     | USCE Palouse Basin Project              | VII-22 |
|     | Summary                                 | VII-25 |

|      |  |         |
|------|--|---------|
| VIII | ORGANIZATION AND FINANCING                           | VIII- 1 |
|      | General  | VIII- 1 |
|      | Operating Structure                                  | VIII- 1 |
|      | Project Financing                                    | VIII- 3 |
|      | U. S. Army Corps of Engineers (USCE)                 | VIII- 4 |
|      | U. S. Bureau of Reclamation (BOR)                    | VIII- 4 |
|      | Department of Housing and Urban<br>Development (HUD) | VIII- 5 |
|      | Soil Conservation Service (SCS)                      | VIII- 6 |
|      | Financial Plan - Snake River                         | VIII- 6 |
|      | Financial Plan - USCE Palouse Basin<br>Project       | VIII-10 |
|      | USCE Financing - Snake River                         | VIII-13 |
| IX   | FINDINGS AND RECOMMENDATIONS                         | IX- 1   |
|      | REFERENCES   |         |
|      | APPENDIX   |         |

## LIST OF FIGURES AND PLATES

|              |   |         |
|--------------|---|---------|
| Figure II-1  | Population Growth Projection                                | II- 6   |
| Figure II-2  | Water Demand by User<br>for 1975, 1980, 2000 and 2020       | II- 2   |
| Figure III-1 | General Map of Surface Water Resources                      | III- 3  |
| Figure VI-1  | Typical Conjunctive Use Plan                                | VI- 3   |
| Figure VI-2  | Typical High Lift Pumping Plant<br>(Wawawai)                | VI- 7   |
| Figure VI-3  | Typical Water Treatment Plant<br>Flow Sheet                 | VI- 9   |
| Figure VII-1 | Alternative Plans for Water Supply<br>Location Map A        | VII- 3A |
| Figure VII-2 | Alternative Plans for Water Supply<br>Location Map B        | VII- 3B |
| Plate 1      | Palouse Basin Project                                       | VII-28  |
| Plate 2      | Palouse Basin Project                                       | VII-29  |
| Plate 3      | U. S. C. E. Palouse Basin Project                           | VII-30  |
| Plate 4      | U. S. C. E. Palouse Basin Project<br>Troy Watershed Project | VII-31  |
| Plate 5      | Troy Watershed Project                                      | VII-32  |
| Plate 6      | Snake River Project   | VII-33  |

## LIST OF TABLES

|           |   | <u>Page</u> |
|-----------|---|-------------|
| Table 2-1 | P-MWRC Population Trends  | II- 3       |
| Table 2-2 | Pullman-Washington State University<br>Population Projections     | II- 5       |
| Table 2-3 | Moscow-University of Idaho and<br>Combined Population Projections | II- 7       |
| Table 2-4 | Summary of Area Consumption                                       | II- 8       |
| Table 2-5 | Projected Total Water Demand                                      | II- 9       |
| Table 3-1 | Summary of Surface Water Resources                                | III- 2      |
| Table 3-2 | Water Quality Snake River at Wawawai                              | III- 5      |
| Table 3-3 | Water Quality North Fork Palouse<br>River at Palouse              | III- 6      |
| Table 3-4 | Water Quality Potlatch River<br>at Kendrick                       | III- 7      |
| Table 5-1 | Palouse Storage Sites   | V- 2        |
| Table 5-2 | Summary of USCE Annual Costs<br>for M & I Use                     | V- 3        |
| Table 7-1 | Snake River Alternate Project<br>Cost Summary                     | VII- 9      |
| Table 7-2 | Palouse Basin Alternate Project<br>Cost Summary                   | VII-11      |



|           |  |         |
|-----------|--|---------|
| Table 7-3 | Physical Data on Proposed<br>Dams and Reservoirs     | VII-14  |
| Table 7-4 | Troy Watershed Alternate<br>Capital Cost Summary     | VII-17  |
| Table 7-5 | Potlatch Cost Summary                                | VII-20  |
| Table 7-6 | Clearwater Cost Summary                              | VII-23  |
| Table 7-7 | USCE Palouse Basin Alternate<br>Project Cost Summary | VII-26  |
| Table 7-8 | Summary of Major Facilities                          | VII-27  |
| Table 7-9 | Summary of Capital Costs                             | VII-28  |
| Table 8-1 | Snake River Project<br>Financial Plan A              | VIII- 7 |
| Table 8-2 | Snake River Project<br>Financial Plan B              | VIII- 8 |
| Table 8-3 | USCE Palouse Basin Project<br>Financial Plan C       | VIII-11 |

## INTRODUCTION

### STUDY AUTHORIZATION

Historically, all domestic waters required for the Pullman-Moscow urban area have been taken from the ground water basin underlying the region. Recent hydrological and geophysical studies have indicated that the ground water in the Pullman-Moscow basin is being substantially depleted by domestic consumption and could possibly become exhausted before the year 2000. Initial action was taken to resolve the problem and assure availability of a future supply in August, 1966, with the formation of the Pullman-Moscow Water Resource Committee (P-MWRC). The P-MWRC is composed of two members from each of the four legal entities responsible for the major supply of domestic water within the area and includes the City of Pullman, the City of Moscow, the University of Idaho and Washington State University. The purpose of the committee is to study and recommend possible methods of augmenting the ground water supply currently being employed for domestic use. To assist in this accomplishment, the P-MWRC retained Stevens, Thompson & Runyan, Inc., Consulting Engineers, in January, 1970, to undertake an independent study and prepare a report on the feasible sources of surface water which could possibly be developed to augment the present water supply.

The intent of the study is not to imply that any separate entity should provide the major water supply to the entire area, but in the interests of economy and environmental compatibility, the project might be approached from the standpoint of developing a mutual and cooperative solution.

### SCOPE

The major emphasis of the engineering report was to be placed on a comparative analysis of all feasible surface water supplies which could be utilized as a common source of domestic water without use of wells. However, in the course of the study, it was determined that

an economical solution was not possible without conjunctive use of existing wells on a continuous basis. Thus, conjunctive use of the present wells plus the potential use of low-quality water sources were considered for peaking purposes with the recommendation of the two most favorable sources of surface water. Either of these sources could be deemed feasible to totally provide the entire urban area's annual demand. Development plans for additional ground water supplies were not to be considered.

Additional factors considered by the study included the following:

1. Review and evaluation of the population and water demand projections prepared by the P-MWRC, both prior and during the study period.
2. Review and evaluation of the projects on the North Fork of the Palouse River as outlined and presented by the United States Army Corps of Engineers (USCE).
3. Contacting and maintaining liaison with all interested communities and governmental agencies involved.
4. Recommendation of possible methods of operation for any proposed water utility.

## OBJECTIVES

As previously indicated, the primary objective of this study is the selection of one or more alternatives which would provide the urban area with an economical and reliable source of domestic water. Direction of future study and information on the existing wells and aquifer is an indirect objective of this study. Since the potential use of a surface supply of water could permit the existing wells to be relieved of major production responsibilities, observation and study of the recovery characteristics of the wells and the aquifer could still provide valuable information about the capacity of that aquifer. Additionally, the study will serve as a comprehensive and independent analysis of the water shortage problem and the potential solutions.

## STUDY DEVELOPMENT

Information on population, water consumption and the existing water systems was gathered for engineering studies. From this data, design parameters and preliminary designs for all feasible water sources were developed. Cost estimates of each alternative were made in a manner which permitted relative economic comparison of the alternate sources with the most favorable sources being fully developed for presentation in this report. Final recommendations were based on careful examination of possible financial plans, project scheduling requirements, long-range flexibility, environmental analysis and additional multiple-use benefits to be achieved.

## AREA TO BE SERVED

The ultimate service area considered and defined for the study and planning was not dictated by political boundaries but by the population growth and development of urban communities and associated educational institutions. It is significant to note that agreement and cooperation encompasses environs in two states.

Early in the study, questionnaires were sent to eleven other communities within the general area. The basic purpose of the questionnaire was to inform the communities of the study and determine if such communities could possibly make use of the proposed new water supply. Seven responses to the questionnaire were received which included negative reactions from the communities of Colton, Colfax, Kendrick and Uniontown. The communities of Palouse, Albion and Troy indicated an interest in an additional source of water within the next five to fifteen years. However, the volume of water which might be required in each case is insignificant compared to the total amount required for the Pullman-Moscow area. The sample questionnaire and letters received may be found in the report appendix.

Contacts were made with numerous state and federal agencies on behalf of the study. The Washington State Department of Water Resources and the Idaho State Department of Reclamation reviewed problems of existing and future water rights. Meetings were held

with the Planning Staff of the Idaho Water Resources Board (IWRB) in order to coordinate the study with that agency's planning efforts, and also with the Idaho Fish and Game Department to obtain its reaction to the various alternatives being investigated. The Walla Walla District Office of the USCE provided information relative to the evaluation of their proposed project, and a meeting was held with the Troy Watershed Development Committee to review the status of the study and the methods being used to evaluate that particular alternative. Population data was solicited from the Washington State Highway Department and the Whitman Regional Planning Council. Inquiries made to the Department of Housing and Urban Development, Soil Conservation Service and Bureau of Reclamation brought information on project financial assistance.

#### INFORMATION AND DATA AVAILABLE

In the preparation of this report, full use has been made of previous reports, records, statistical information, maps and other data furnished by the P-MWRC as well as other agencies. Where utilized or reviewed, this information has been referenced or acknowledged. Base maps for preliminary layouts utilized published and preliminary topographic maps of the U. S. Geological Survey.

## NOMENCLATURE

|       |   |                            |
|-------|---|----------------------------|
| AF    | - | acre feet                  |
| BG/YR | - | billion gallons per year   |
| bgy   | - | billion gallons per year   |
| cfs   | - | cubic feet per second      |
| gpcd  | - | gallons per capita per day |
| gpm   | - | gallons per minute         |
| hp    | - | horsepower                 |
| JTU   | - | Jackson candle unit        |
| KWH   | - | Kilowatt hour              |
| M & I | - | municipal and industrial   |
| MAR   | - | mean annual runoff         |
| mg    | - | million gallons            |
| mg/l  | - | milligrams per liter       |
| mgd   | - | million gallons per day    |
| ml    | - | milliliters                |
| msl   | - | mean sea level             |
| rpm   | - | revolutions per minute     |
| WTP   | - | water treatment plant      |
| umho  | - | micro-umhos                |

## POPULATION GROWTH AND FUTURE WATER DEMAND

### GENERAL

At the outset of this study, the Pullman-Moscow Water Resources Committee supplied population data for use in development of the water resources plan. The intent of this section of the report is analysis and summary of these projections and adjustments thereto, resulting in the base data necessary to the conduct of the study.

The final projections are subject to certain limitations and should only be considered as probable levels of future activity given past and present trends and certain factors concerning their continuation. It is also important to note that these projections are subject to certain basic assumptions as follows: heavy industry will not develop to any appreciable extent, and the two urban areas will be mainly dependent on the universities for an economic base and growth; light industries and commercial enterprises of a technological nature can be expected because of the presence of the universities but can not be projected because of a lack of historical trend; Washington State University enrollment will stabilize in line with current policy to limit enrollment of a given institution; and finally, the projections are oriented only toward the Pullman and Moscow areas, even though other outlying areas may be involved.

### AVAILABLE DATA

Numerous projection procedures are available, including the use of straight line projections, logarithmic trends, constant rate of change projections, the cohort-survival and other more sophisticated mathematical projection techniques. A large multi-economic base population and adequate historic internal trends are the basis for these expressions. This, however, is not the case with either of the two cities under consideration. Pullman has a current population of

22,000, of which only 3,330 or approximately 15% are not directly connected with the University. In Moscow, Idaho, a slightly higher percentage of population is not oriented toward the University. The 1970 census indicated a combined population of 13,731. Thus, university enrollments provide an extremely important external influence, and it becomes readily evident that the conventional population projection techniques must be modified for the Pullman-Moscow study area.

The information supplied for this study varied widely. The U. S. Bureau of Census data has been updated by a special census in the state of Washington, and an update for Moscow is available for 1965. Previous analyses for Moscow/University of Idaho include three reports completed before 1960 and recent information gathered for the Pullman-Moscow Water Resources Committee. The information provided for the Pullman/Washington State University area is quite thorough and includes detailed projections. The latter reflect the impact of the rapid state university enrollment expected in the next few years. 1970 census data was not sufficiently complete in time for this study other than for overall comparison purposes.

#### P-MWRC PROJECTIONS

The population trends for Pullman/Washington State University completed by Abbey & Copp (10) and the Washington State University office of University Development are thorough in their analysis of the university structure and its relationship to the city. The former report has been projected to the year 2020, while the report by the Office of University Development projected only to the year 1980. The Abbey & Copp projection is based on a methodology consisting of projections of ten factors, ranging from student enrollment through staff and faculty to city population. Utilizing projections of student enrollment and ratios of students to faculty and staff, spouses, and dependents, the full size of the university community can be approximated. The non-university population is projected independently based on economic base trends. If for some reason, the enrollment of a university were fixed at a certain level, the projections computed would be altered and may not reach the ranges shown within the same time frame.



Total and combined population growth trends for the study area developed by the P-MWRC are summarized in Table 2-1.

TABLE 2-1  
P-MWRC POPULATION TRENDS

|               | <u>1980</u> | <u>2000</u> | <u>2020</u> |
|---------------|-------------|-------------|-------------|
| HIGH ESTIMATE | 49,500      | 74,000      | 104,000     |
| LOW ESTIMATE  | 47,500      | 61,000      | 72,300      |

#### PREPARATION OF AREA PROJECTIONS

More recent basic projection data, including those developed as a part of this study, vary somewhat from the data in the Abbey & Copp work. Therefore, while the latter approach was considered valid and adopted for use in this study, revised trends have been computed and presented in Tables 2-2 through 2-3 and Figure II-1.

As indicated above there are significant limitations in available data on the Moscow/University of Idaho area. Because of this situation it was necessary to develop new projections that could be used as base data compatible to the Pullman/Washington State University data. These population trends were based on available historical data and University of Idaho future enrollment estimates. In view of the similarities between the Pullman and Moscow urban areas, it was concluded that the same projecting methodology utilized for the Pullman/Washington State University would be appropriate for the Moscow/University of Idaho community.

The trend as summarized in Table 2-3, was initiated by projecting University of Idaho enrollment from past, present, and near future enrollment as provided by the Department of Institutional Research at the University of Idaho. Since the projections available were only carried to 1979, it was necessary to continue the projection to the year 2020. The results are summarized in line one of Table 2-3.

Based on ratios relating the student enrollment to the required number of faculty and staff as developed for Washington State University, the number of faculty and staff was determined. Using the assumption that the dependent family of each faculty and staff member consisted of two additional members, line 3 was also calculated.

Utilizing a similar methodology, the number of married students and their families was calculated. The family size in this instance was assumed to be an additional 1.5 persons as opposed to two persons for faculty and staff. Finally, the "City" or non-university related population is the result of projections of past "City" populations and possible trends as indicated by the USCE Economic Base Study (21), or about a 1.0-1.5% increase per year.

Total or combined low and high population trends are summarized in Table 2-3, and presented in Figure II-1. Particularly evident from the curves are the significant effect of high rate of enrollment increase at WSU expected through 1980, and the subsequent leveling to about a 1% annual growth. In this latter period the upward trend for Pullman/Washington State University is dependent on area economy factors other than the University. Moscow/University of Idaho exhibits a normal growth curve. A doubling time for the total area population is estimated at twenty-eight years compared to the previous doubling period of twenty-two years.

It should be noted that although there are similarities between the Pullman/Moscow areas, there are also differences that may influence the projections. The State of Idaho currently operates under a more lenient policy than Washington regarding the upper limit on university enrollment; state fiscal resources and monetary policies differ; and there is the 1.3 to 1.0 ratio of non-students to student enrollment in the Moscow area as opposed to a ratio of 0.9 to 1.0 in the Pullman area. Although these differences are evident, it is not anticipated that they will adversely influence the basic composite population trends developed.

TABLE 2-2  
PULLMAN-WASHINGTON STATE UNIVERSITY  
POPULATION PROJECTIONS

| <u>Low Projection</u>   | <u>1970</u> | <u>1975</u> | <u>1980</u> | <u>1990</u> | <u>2000</u> | <u>2010</u> | <u>2020</u> |
|---|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| A. Total Enrollment   | 13,136      | 19,200      | 24,000      | 28,000      | 28,000      | 28,000      | 28,000      |
| B. Faculty and Staff <sup>1</sup>                               | 2,955       | 4,376       | 5,619       | 6,580       | 6,580       | 6,580       | 6,580       |
| C. Faculty and Staff Families <sup>2</sup>                      | 5,910       | 8,752       | 11,238      | 13,160      | 13,160      | 13,160      | 13,160      |
| D. Married Students <sup>3</sup>                                | 2,107       | 3,220       | 4,350       | 5,600       | 5,600       | 5,600       | 5,600       |
| E. Student Families <sup>4</sup>                                | 3,161       | 4,850       | 6,525       | 8,400       | 8,400       | 8,400       | 8,400       |
| F. Enrolled Spouses of Students, Faculty and Staff <sup>5</sup> | 1,287       | 1,886       | 2,370       | 2,766       | 2,766       | 2,766       | 2,766       |
| G. "City" Population <sup>6</sup>                               | 3,310       | 3,479       | 3,656       | 4,038       | 4,460       | 4,926       | 5,441       |
| TOTAL (A+B+C+E+G-F)   | 27,185      | 38,751      | 48,668      | 57,412      | 57,834      | 58,300      | 58,815      |
| <u>High Projection</u>  | <u>1970</u> | <u>1975</u> | <u>1980</u> | <u>1990</u> | <u>2000</u> | <u>2010</u> | <u>2020</u> |
| A. Total Enrollment   | 14,290      | 20,350      | 25,000      | 29,000      | 30,000      | 30,000      | 30,000      |
| B. Faculty and Staff <sup>1</sup>                               | 3,215       | 4,668       | 5,896       | 6,825       | 7,060       | 7,060       | 7,060       |
| C. Faculty and Staff Families <sup>2</sup>                      | 6,430       | 9,336       | 11,792      | 13,650      | 14,120      | 14,120      | 14,120      |
| D. Married Students <sup>3</sup>                                | 2,279       | 3,485       | 4,625       | 5,800       | 6,000       | 6,000       | 6,000       |
| E. Student Families <sup>4</sup>                                | 3,418       | 5,228       | 6,938       | 8,700       | 9,000       | 9,000       | 9,000       |
| F. Enrolled Spouses of Students, Faculty and Staff <sup>5</sup> | 1,400       | 2,001       | 2,472       | 2,866       | 2,965       | 2,965       | 2,965       |
| G. "City" Population <sup>7</sup>                               | 3,310       | 3,474       | 3,646       | 4,074       | 4,551       | 5,299       | 6,169       |
| TOTAL (A+B+C+E+G-F)   | 29,263      | 41,055      | 50,800      | 59,383      | 61,766      | 62,514      | 63,384      |

1. Lower Division, 17:1, Upper Division, 11:1, and Graduate, 5:1; Staff, 7.3:1 to 4.25:1 after 1990

2. 2.0 x Faculty and Staff


3. 10% of Under Graduate Staff and 60% of Graduate; 20% of total after 1990

4. 1.5 x Married Students

5. 8% of Students, Faculty and Staff

6. 1.00% per year

7. 0.95% per year to 1980, 1.1% per year to 2000, and 1.55% per year to 2020



**POPULATION GROWTH  
PROJECTION**

**Stevens, Thompson & Runyan, Inc.**

*Engineers/Planners*

PORTLAND

SEATTLE

BOISE



FIGURE II-1

TABLE 2-3  
MOSCOW-UNIVERSITY OF IDAHO AND COMBINED  
POPULATION PROJECTIONS

| <u>Low Projection</u>             | <u>1970</u> | <u>1975</u> | <u>1980</u> | <u>1990</u> | <u>2000</u> | <u>2010</u> | <u>2020</u> |
|-----------------------------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| A. Total Enrollment               | 6,460       | 7,140       | 7,800       | 9,500       | 11,500      | 13,600      | 15,700      |
| B. Faculty and Staff              | 1,400       | 1,550       | 1,700       | 2,100       | 2,500       | 3,000       | 3,500       |
| C. Faculty and Staff Families     | 2,800       | 3,100       | 3,400       | 4,200       | 5,000       | 6,000       | 7,000       |
| D. Married Students               | 920         | 1,070       | 1,170       | 1,400       | 1,750       | 2,100       | 2,400       |
| E. Student Families               | 1,380       | 1,605       | 1,755       | 2,500       | 2,625       | 3,150       | 3,600       |
| F. Enrolled Spouses               | 629         | 695         | 760         | 928         | 1,120       | 1,328       | 1,536       |
| G. Projected "City"<br>Population | 3,400       | 3,573       | 3,755       | 4,148       | 4,582       | 5,061       | 5,590       |
| TOTAL (A+B+C+E+G-F)               | 14,811      | 16,273      | 17,650      | 21,120      | 25,087      | 29,483      | 33,854      |
| <u>High Projection</u>            | <u>1970</u> | <u>1975</u> | <u>1980</u> | <u>1990</u> | <u>2000</u> | <u>2010</u> | <u>2020</u> |
| A. Total Enrollment               | 6,460       | 7,300       | 8,200       | 10,600      | 13,000      | 16,400      | 20,000      |
| B. Faculty and Staff              | 1,400       | 1,585       | 2,200       | 2,800       | 3,500       | 4,400       | 5,400       |
| C. Faculty and Staff Families     | 2,800       | 3,170       | 4,400       | 5,600       | 7,000       | 8,800       | 10,000      |
| D. Married Students               | 1,100       | 1,095       | 1,500       | 2,000       | 2,400       | 3,000       | 3,600       |
| E. Student Families               | 1,650       | 1,643       | 2,250       | 3,000       | 3,600       | 4,500       | 5,400       |
| F. Enrolled Spouses               | 629         | 712         | 832         | 1,072       | 1,320       | 1,664       | 2,032       |
| G. Projected "City"<br>Population | 3,400       | 3,568       | 3,744       | 4,183       | 4,673       | 5,440       | 6,334       |
| TOTAL (A+B+C+E+G-F)               | 15,081      | 16,554      | 19,962      | 25,111      | 30,453      | 37,876      | 45,102      |
| <u>Combined Projections</u>       | <u>1970</u> | <u>1975</u> | <u>1980</u> | <u>1990</u> | <u>2000</u> | <u>2010</u> | <u>2020</u> |
| Low Population                    | 41,996      | 55,024      | 66,318      | 78,532      | 82,921      | 87,783      | 92,669      |
| High Population                   | 44,344      | 57,609      | 70,762      | 84,494      | 92,219      | 100,390     | 108,486     |
| Mean Population                   | 43,170      | 56,317      | 68,540      | 81,513      | 87,570      | 94,087      | 100,578     |

TABLE 2-4  
SUMMARY OF AREA CONSUMPTION

| YEAR | CITY OF PULLMAN      |                      |                      | WSU                  |                      |                      | MOSCOW               |                      |                      | U. OF I.             |                      |                      |
|------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|----------------------|
|      | Ave.<br>Day<br>(mgd) | Max.<br>Day<br>(mgd) | Min.<br>Day<br>(mgd) | Ave.<br>Day<br>(mgd) | Max.<br>Day<br>(mgd) | Min.<br>Day<br>(mgd) | Ave.<br>Day<br>(mgd) | Max.<br>Day<br>(mgd) | Min.<br>Day<br>(mgd) | Ave.<br>Day<br>(mgd) | Max.<br>Day<br>(mgd) | Min.<br>Day<br>(mgd) |
| 1954 | 0.95                 |                      |                      | 0.89                 |                      |                      |                      |                      |                      |                      |                      |                      |
| 1955 | 1.08                 |                      |                      | 0.86                 |                      |                      |                      |                      |                      |                      |                      |                      |
| 1956 | 1.11                 |                      |                      | 1.02                 |                      |                      |                      |                      |                      |                      |                      |                      |
| 1957 | 1.11                 |                      |                      | 1.10                 |                      |                      |                      |                      |                      |                      |                      |                      |
| 1958 | 1.17                 |                      |                      | 1.02                 |                      |                      | 1.03                 |                      |                      |                      |                      |                      |
| 1959 | 1.02                 |                      |                      | 1.11                 |                      |                      | 1.11                 |                      |                      |                      |                      |                      |
| 1960 | 1.14                 | 3.28                 |                      | 1.14                 |                      |                      | 1.17                 |                      |                      |                      |                      |                      |
| 1961 | 1.29                 |                      |                      | 1.21                 |                      |                      | 1.15                 |                      |                      |                      |                      |                      |
| 1962 | 1.11                 | 3.34                 |                      | 1.34                 |                      |                      | 1.37                 | 3.53                 |                      |                      |                      |                      |
| 1963 | 1.29                 |                      |                      | 1.45                 |                      |                      |                      |                      |                      |                      |                      |                      |
| 1964 | 1.23                 | 3.42                 |                      | 1.46                 |                      |                      | 1.12                 |                      |                      |                      |                      |                      |
| 1965 | 1.37                 |                      |                      | 1.56                 |                      |                      | 1.20                 |                      |                      | 0.43                 |                      |                      |
| 1966 | 1.55                 |                      |                      | 1.64                 |                      |                      | 1.38                 |                      |                      | 0.48                 |                      |                      |
| 1967 | 1.63                 | 4.01                 | 0.83                 | 1.71                 | 4.02                 | 0.72                 | 1.48                 | 3.42                 | .47                  | 0.52                 |                      |                      |
| 1968 | 1.62                 | 4.58                 | 0.85                 | 1.68                 | 4.51                 | 1.20                 | 1.45                 | 3.94                 | .41                  | 0.47                 | 1.74                 | 0.11                 |
| 1969 | 1.95                 | 4.51                 | 0.80                 |                      |                      |                      |                      | 3.77                 | .36                  | 0.46                 | 2.01                 | 0.14                 |

8-II

Data available as of January, 1970, and estimated in part where records were incomplete or compiled by different methods.

## PROJECTED WATER DEMAND




Water requirements for the P-MWRC study area include daily and seasonal variables, consumptive trends and the impact of other than domestic consumption such as sprinkling, agricultural and air conditioning uses. Examination of historical records indicates a wide variation in maximum and agricultural uses; however, such use is seasonal with enrollment. Data for the past fifteen years are summarized in Table 2-4. Mean rates for the total area were calculated to be 173 gallons per day per capita with a peak day to average day ratio of 2.85 and minimum day to average day ratio of 0.50. Per capita rates varied with community and over the years of record from 135 to 190 gallons per day.

For purposes of comparison the results of a national survey by Linaweaver, et al. (7), for western communities with heavy sprinkling demands were evaluated. Use of the Linaweaver statistical equations indicated an average consumptive demand of 174 gallons per day per capita and a peak day ratio of 3.12 for the Pullman/Moscow area.

In projecting the consumptive trends, it is generally accepted that per capita rates of consumption will continue to increase. Taking the available data and foregoing factors into consideration, per capita consumption was established for future use as 175 gpcd in 1975 increasing uniformly to 200 gpcd in the year 2020. Peak usage including unaccountable losses was set as 3.0 times the average daily demand. Projected total demands through the year 2020, suitable for design use, have been summarized in Table 2-5 below.

TABLE 2-5  
PROJECTED TOTAL WATER DEMAND

| <u>Year</u> | <u>Per Capita</u> | <u>Average Day<br/>mgd</u> | <u>Peak Day<br/>mgd</u> | <u>Total Annual Requirement</u> |                        |
|-------------|-------------------|----------------------------|-------------------------|---------------------------------|------------------------|
|             |                   |                            |                         | <u>Acre-Feet</u>                | <u>Million Gallons</u> |
| 1970        | 170               | 7.55                       | 22.7                    | 8,470                           | 2,760                  |
| 1975        | 175               | 9.86                       | 29.6                    | 11,050                          | 3,600                  |
| 1980        | 180               | 12.3                       | 37.0                    | 13,810                          | 4,500                  |
| 1990        | 185               | 15.1                       | 45.2                    | 16,880                          | 5,500                  |
| 2000        | 190               | 16.6                       | 49.9                    | 18,630                          | 6,070                  |
| 2010        | 195               | 18.4                       | 55.0                    | 20,560                          | 6,700                  |
| 2020        | 200               | 20.1                       | 60.4                    | 22,530                          | 7,340                  |



**WATER DEMAND BY USER  
FOR 1975, 1980, 2000 AND 2020**

Stevens, Thompson & Runyan, Inc.

Engineers/Planners

PORTLAND

SEATTLE

BOISE



FIGURE II-2



These demands are the amount to be supplied from any potential source or combination of sources for a specific user or combination of users as shown. It should be noted that the equivalent population served differs from resident population for any particular user because of off-campus living, or residences, plus the fact that in some cases city systems provide water to university systems. This distribution of water demand for the years 1975, 1980, 2000 and 2020 is depicted in Figure II-2. For example, in 1975, Pullman will be serving an equivalent population of 25,400 or a supply of 4.6 mgd. This is about 41% of the combined demand. This ratio will remain fairly constant through 2020 when the average demand for Pullman will total 8.2 mgd.

## CONCLUSIONS

Continued development and growth of the Pullman and Moscow communities and thus the needs of additional water supply will be dependent on conditions which consist of the following:

1. Near future population projections are primarily related to university enrollments and growth, particularly Washington State University which may increase nearly fifty per cent in the next five years.
2. Per capita water consumption rates will continue to increase annually, as long as the cost of water remains near present levels, reaching a rate of 200 gpcd by 2020.
3. Average daily demand on an annual basis should reach 15 mgd by 1990 and 20 mgd by 2020. Peak usage during the summer and early fall seasons will require 3.0 times the average demand.
4. The largest demand will be by the City of Pullman, reaching nearly 4.5 mgd in 1975 and 8.2 mgd in 2020.

## WATER SUPPLY SOURCES

### GENERAL

Consideration as to available sources of supply, their probable yield and water quality was given to all major surface water sources within a 40 mile radius of the Pullman-Moscow area. Criteria for selection and review of a potential source included that it 1) be a surface supply, 2) be able to provide the maximum development requirements, 3) should have limited existing water rights, and 4) be a potentially approved water supply source as far as health standards were concerned.

For the volumes of water projected for domestic use, the long transportation distances and the seasonal extremes in runoff conditions, it was determined that surface water should be stored at the source in order to meet the summer peak demands. Combinations of watersheds were considered to meet required yields for potential water supply sources in addition to individual watersheds and specific storage sites.

### AVAILABLE SOURCES

Within the area of study, five different sources were selected for serious consideration. A number of these also had several alternate methods of development. These potential sources, shown in Figure 3-1, lie within four distinct drainage basins or sub-basins: the Snake River, the Clearwater River, the Potlatch River and the Palouse River.

Aside from the distance from the center of the area of distribution, the sites can be characterized by their elevation differences relative to Pullman-Moscow, availability of storage sites, minimum stream flows, raw water quality, regulation of watershed development and existing water rights. Some of these factors have been summarized in Table 3-1. Characteristics such as water treatment requirements, water quality or elevation differences greatly affect the engineering


TABLE 3-1  
SUMMARY OF SURFACE WATER RESOURCES

| Source   | Drainage Area<br>Sq. Mi. | Approx. Elevation<br>above msl | Distance From<br>P-M, Mi | Minimum Flow<br>cfs | Water Quality | Treat-ment<br>Required | Water Rights          | Comments                           |
|--|--------------------------|--------------------------------|--------------------------|---------------------|---------------|------------------------|-----------------------|------------------------------------|
| Snake River at Wawawai                         | 103,500                  | 735                            | 15.4                     | 9000                | Ave.          | B                      | USCE Permit           | Withdrawal From Lower Granite Pool |
| Palouse River at Elberton                      | 406                      | 2200                           | 18.1                     | 2                   | Poor          | C                      | Not Fully Adjudicated | Storage Required                   |
| Palouse River at Palouse                       |                          | 2432                           | 12.2                     | 2                   | Poor          | C                      | Not Fully Adjudicated | Storage and Regulation Required    |
| Palouse River at Princeton                     | 317                      | 2500                           | 17.5                     | 2 <sup>1</sup>      | Ave.          | B                      | Not Fully Adjudicated | Storage and Regulation Required    |
| III-2 Palouse River at Harvard                 |                          | 2560                           | 22.0                     | 2 <sup>1</sup>      | Ave.          | B                      | Not Fully Adjudicated | Storage Required                   |
| Palouse River at Laird                         | 65                       | 2700                           | 25.6                     | 2 <sup>1</sup>      | Excel.        | A-B                    | USFS Controlled       | Storage Required                   |
| Moscow Mt. Watershed near Troy                 | 75                       | 2700                           | 15.5                     | NA                  | Ave.          | B                      | Purchase Required     | Storage Required                   |
| Potlatch River at Helmer                       | 121                      | 2620                           | 29.0                     | 8 <sup>1</sup>      | Excel.        | A-B                    |                       | Storage and Regulation Required    |
| Clearwater River at Arrow                      | 9570                     | 900                            | 23.0                     | 500                 | Good          | B                      | USCE Permit           |                                    |
| Clearwater River at Dworshak Dam               | 2400                     | 1600                           | 39.0                     | 655 <sup>1</sup>    | Excel.        | A-B                    | USCE Permit           | Withdrawal From Dworshak Pool      |
| Palouse River at Moscow Sewage Treatment Plant | NA                       | 2500                           | 3.0                      | 2                   | Poor          | D                      | None                  | Tertiary Treatment Required        |

1] Limited records available.


# GENERAL MAP OF SURFACE WATER RESOURCES

WATER STUDY  
PULLMAN-MOSCOW  
WATER RESOURCES COMMITTEE



### LEGEND

- 5 — DISTANCE FROM CENTER OF DISTRIBUTION
- WATERSHED AREA BELOW ELEVATION 2000
- WATERSHED AREA ABOVE ELEVATION 3000
- MAJOR DRAINAGE BASIN BOUNDARY



**Stevens, Thompson & Runyan, Inc.**  
Engineers/Planners  
PORTLAND SEATTLE BOISE

FIGURE III-1

decision making. Sources below the 2000-foot elevation require major pumping schemes, while sources in the same elevation zone or above allow some gravity conveyance. For purposes of this study and the summary in Table 3-1, treatment requirements were determined to be:

- A. Filtration and chlorination
- B. Coagulation, filtration and chlorination
- C. Coagulation, activated carbon addition, filtration and chlorination
- D. Complete water reclamation (applicable to reuse of sewage effluent)

### WATER QUALITY

Water quality data and summary reports are available for certain stations within the study area. Information obtained from both the records of the Federal Water Quality Administration and U. S. Geological Survey - Water Resources Division through January, 1970, were evaluated in this review. These Data have been summarized for three major drainage basins regarded as potential sources in Tables 3-2 through 3-5. Averages shown are based on all seasons and years of data available. Maximum and minimum values are for the period 1965-1969 or five years. Stations considered important for this study were the following:

Snake River at Wawawai  
Palouse River at Palouse  
Palouse River at Princeton  
Potlatch River at Kendrick

Comparisons of the measured raw water characteristics to standards for drinking water and acceptable ranges for raw water are indicated for each source. Sources with biological characteristics exceeding acceptable limits would be considered marginal sources and require higher degree of treatment and annual expense but still might be made available at a lower cost than a more distant source or one requiring higher pumping heads.

TABLE 3-2  
WATER QUALITY  
SNAKE RIVER AT WAWAWAI

| <u>Item</u>                          | <u>Mean<br/>Recorded</u> | <u>Maximum<br/>Recorded</u> | <u>Minimum<br/>Recorded</u> | <u>Acceptable<br/>Range<br/>Of Raw Water<br/>For M &amp; I Use<sup>1</sup></u> | <u>PHS<br/>Drinking Water<br/>Standards</u> | <u>Desired<br/>Treated<br/>Water<br/>Quality</u> |
|--------------------------------------|--------------------------|-----------------------------|-----------------------------|--|---|--|
| Dissolved Oxygen, mg/l               | 11.3                     | 13.8                        | 7.0                         | 5.0  |   | 5.0-7.5  |
| Dissolved Oxygen, % Sat.             |                          | 107                         | 77                          | 70   |   | 75   |
| pH, Std. Units                       | 7.7                      | 9.0                         | 6.8                         | 6.5-8.5  |   | 6.5-8.5  |
| Temp, °C                             | 11.9                     | 25.0                        | 2.5                         | 20   |   | 20   |
| Turbidity, JTU                       | 4.2                      | 305                         | 0.2                         | 10-250   | 5   | 1.0  |
| Specific Con, umho                   | 255                      | 417                         | 67                          | 300  |   | 300  |
| Color, Std. Units                    | 18                       | 40                          | 1                           | 75   | 15  | 3  |
| Coliforms/100 ml.                    | 655                      | 10,000                      | 25                          | 5,000  | 1.0   | none   |
| Total Hardness, mg/l                 | 95                       | 189                         | 21                          | 270  |   | 100  |
| Calcium Hardness, mg/l               | 83                       | 135                         | 12                          | 175  |   | 125  |
| Chlorides, mg/l                      | 20                       | 17                          | 1                           | 15   | 250   | 15   |
| Phosphates, mg/l <sup>2</sup>        | .19                      | .72                         | .01                         | .044   |   |  |
| Nitrogen, as N, mg/l <sup>2</sup>    | 1.20                     | 4.0                         | 0.3                         | .034   | 10  | 10   |
| Total Dis. Solids, mg/l <sup>3</sup> | 165                      | 270                         | 44                          | 200  | 500   | 200  |
| BOD 5 day, mg/l                      |                          | 3.2                         | 0.1                         |  |   |  |

1] California Water Quality Criteria & University of Illinois Conference on Raw Water Characteristics( 8 )(25).

2] To minimize algae in raw water storage.

3] Computed, based on 0.65 x specific conductance, where not available.

TABLE 3-3  
WATER QUALITY  
NORTH FORK PALOUSE RIVER AT PALOUSE

| <u>Item</u>                          | <u>Mean<br/>Recorded</u> | <u>Maximum<br/>Recorded</u> | <u>Minimum<br/>Recorded</u> | <u>Acceptable Range<br/>Of Raw Water<br/>For M &amp; I Use<sup>1</sup></u> |
|--------------------------------------|--------------------------|-----------------------------|-----------------------------|--|
| Dissolved Oxygen, mg/l               | 9.8                      | 12.7                        | 5.6                         | 5.0  |
| pH, Std. Units                       | 7.1                      | 7.4                         | 6.8                         | 6.5-8.5  |
| Turbidity, JTU                       | 18                       | 35                          | 3                           | 10-250   |
| Specific Cond., umho                 | 83                       | 122                         | 35                          | 300  |
| Coliforms/100 ml.                    | 4,000                    | 10,900                      | 700                         | 5,000  |
| Total Hardness, mg/l                 | 23                       | 35                          | 10                          | 270  |
| Phosphates, mg/l <sup>2</sup>        | 0.17                     | 0.22                        | 0.08                        | .04  |
| Nitrogen, as N, mg/l <sup>2</sup>    | 1.1                      | 2.3                         | .05                         | 0.03   |
| Total Dis. Solids, mg/l <sup>3</sup> | 54                       | 79                          | 23                          | 200  |

9-III

See Table 3-2 for footnotes.

TABLE 3-4  
WATER QUALITY  
POTLATCH RIVER AT KENDRICK

| <u>Item</u>                               | <u>Mean<br/>Recorded</u> | <u>Maximum<br/>Recorded</u> | <u>Minimum<br/>Recorded</u> | <u>Acceptable Range<br/>Of Raw Water<br/>For M &amp; I Use</u> |
|---|--------------------------|-----------------------------|-----------------------------|--|
| pH, Std. Units                            | 6.9                      | 7.2                         | 6.6                         | 6.5-8.5  |
| Temp °C                                   |                          |                             |                             | 20   |
| Turbidity, JTU                            |                          |                             |                             | 10-250   |
| Specific Cond., umho                      | 66                       | 86                          | 46                          | 300  |
| Color, SU                                 | 7                        | 10                          | 5                           | 75   |
| Coliforms/100 ml.                         |                          |                             |                             | 5000   |
| Total Hardness, mg/l                      | 26                       | 34                          | 19                          | 270  |
| Calcium Hardness, mg/l                    | 23                       | 30                          | 16                          | 175  |
| Chlorides, mg/l                           | 2.3                      | 3.0                         | 1.5                         | 15   |
| Phosphates, mg/l <sup>2</sup>             |                          |                             |                             | .04  |
| Nitrogen, As N, mg/l <sup>2</sup>         | 0.9                      | 1.0                         | 0.8                         | .03  |
| Total Dissolved Solids, mg/l <sup>3</sup> | 64                       | 78                          | 50                          | 200  |

III-7

See Table 3-2 for footnotes.



Most water sources showed higher than acceptable nutrient levels, which can infer seasonal problems in treatment and storage of raw water. The only potential source subject to prolonged storage immediately prior to treatment is the Snake River. Algal blooms in the Lower Granite Pool could occur. Low flow periods of the Palouse could also present algal problems even with regulated release from an upstream reservoir.

Silt loads can be expected to be a seasonal problem for all potential sources. However, additional treatment requirements would not be necessary for plants withdrawing directly from a damsite/reservoir. Regulated releases would not reduce turbidity levels appreciably because of the influence of unregulated tributaries downstream.

Proper development and design of water supply facilities also requires determination of annual runoff and the adequate or "safe" yields of the potential sources as well as estimates of the raw and probable treated water qualities. Factors affecting the estimate of runoffs and safe yields are discussed in Chapter VII where required for development of alternative plans and are not included in this part of the study.

#### ENVIRONMENTAL CONSIDERATIONS

The improvement of the overall water supply system is, of course, the prime concern of this project, and to the greatest extent possible without endangering environmental or natural balances. Past use of the ground water system has in certain instances resulted in a gradual degradation of environmental conditions. For example, where artesian conditions previously existed in the Pullman area contributing to surface streamflow, the water table is now over one hundred feet below the surface in some wells. Proper planning of a large scale surface supply system must undoubtedly be influenced by preservation of environmental quality and minimize any adverse changes as such changes could occur far more rapidly than with ground water systems. Practical questions would be: what impact would be placed on a transfer of 10,000-20,000 acre-feet per year of water from one sub-basin into another? Would a ban on all but minimal use of existing wells improve the hydrological system and yet be both beneficial and

practical? Would downstream stream conditions be improved or degraded from the added wastewater load of different chemical characteristics? Does the economic optimization of a storage reservoir capacity also optimize ecological conditions?

Changes which may occur in the drainage basins may be broadly classified into (a) those that will affect the ecological systems of the area, and (b) those that will affect the inhabitants of the area. The area in each case may be defined to include the watershed, the downstream area of runoff, the communities themselves and downstream areas therefrom. Each of these two classifications will have some effect by water supply development on a large scale.

#### EFFECTS ON ECOLOGICAL SYSTEMS

Operation of nearly all of the proposed projects requires a storage area that will result in flooded cropland or forest land. For single purpose projects for municipal and industrial use, it is felt no significant benefits will be lost but that systems and benefits of a greater magnitude will occur. Here can be noted increased fish propagation, additional waterfowl habitat, increases in general aquatic productivity, and ground water recharge. Multi-purpose storage projects would provide the same advantages with even better control of floods, soil erosion and increased downstream cropland productivity.

Streamflow regulation and wastewater releases would both add improvement to existing conditions by eliminating stagnant areas, providing flushing action and lowering dissolved mineral content. Improvement of certain physical conditions such as flooding, erosion and silt loads could be expected with upstream storage.

## EFFECTS ON INHABITANTS

The proposed projects with potential surface sources will in general improve water supply quality. Dissolved minerals will decrease notably and hardness would be less than one third the amount of the existing well supplies. Mineralization rates of irrigated and sprinkled lands might be reversed in trend with a gradual leaching out of previously stored calcium and other mineral deposits.

Other benefits include diversification of regional recreational opportunities, added employment in rural areas, and general improvement in esthetics and optimal water resource development. The ability to improve downstream water rights during periods of natural low flow should also be considered.

## PREVIOUS STUDIES

### GENERAL

Numerous water studies of supplemental or new sources of domestic water for the communities within the Pullman-Moscow region have been conducted. The scope of most of these studies was not adequate to cover the entire urban area or employed demand requirements now outdated; thus, they were only used herein as references. Three significant previous studies, conducted on behalf of the P-MWRC, were oriented towards the purpose of developing a long range, common surface supply for the entire urban area. A discussion of these reports follows.

### BUREAU OF RECLAMATION STUDY

A preliminary report on water supply in the Pullman-Moscow area was completed in September, 1967, by the U. S. Bureau of Reclamation. This project made reconnaissance level developments of four different sources of surface water for the Pullman-Moscow urban area. Two of the four projects proposed were single-purpose reservoirs, in excess of 30,000 acre-feet, on the North Fork of the Palouse River. Regulated releases would then be diverted at a downstream point near the City of Palouse into a pipeline and pumped to a terminal reservoir located midway between the communities of Pullman and Moscow. A third scheme featured pumping from the main stem of the Snake River to a terminal reservoir located at Pullman with a re-lift pumping station providing water to the City of Moscow. The fourth scheme envisioned pumping water from a single-purpose reservoir on the Potlatch River near Helmer through a transmission line to a terminal reservoir located midway between Pullman and Moscow.

Water demands were determined by the Bureau of Reclamation to the year 2020 based upon the population projections provided by the four legal entities. The study also assumed conjunctive use of ground water from the existing wells to be available and adequate for peaking requirements through the year 2020.

Estimates of annual costs were prepared for each of the four schemes and summarized in the BOR report. Amortization of the initial construction cost was based on federal financing using a 3 1/8% interest rate for a fifty-year period. Annual operating costs were estimated and added to the annual amortization costs to provide total annual costs. The total annual costs were also presented in terms of cost per unit of consumption, which ranged from \$.04/1,000 gal. to \$.07/1,000 gal.

Evaluation of this particular study shows that several factors require discussion. The annual costs which may be anticipated in the first year of operation are 2 1/2 times greater than those anticipated and shown for the year 2020. The annual costs presented do not include construction and operation of treatment facilities or transmission facilities from the terminal reservoir to the communities of Pullman and Moscow. Subsequent projections calculate the total requirements for the year 2020 to be 22,500 acre-feet instead of 18,500 acre-feet as projected in this particular report. Lack of detailed information on the size and capacity of the major components proposed for the four schemes prevents a more thorough analysis of the study.

#### SUTHERLAND STUDY

Dr. Robert A. Sutherland conducted a preliminary examination of four possible sources of surface water which were considered to be adequate supplies for the next fifty years. The report of this study reviews the capacity and capabilities of the existing water systems. Population projections and estimates of future water demands were prepared and used in the development of each alternative. The four different schemes are described and the possible development of each is briefly outlined in narrative. The discussion involves the major physical features of each potential source of supply: development of Hatters Creek near Princeton, the Palouse River above Harvard, the East Fork of Potlatch Creek near Bovill, and the Clearwater River east of Lewiston. The report indicated the source on the Palouse River above Harvard to be preferable.

## CORPS OF ENGINEERS PALOUSE BASIN STUDIES

The Walla Walla District Office of the U. S. Army Corps of Engineers has prepared the most comprehensive study of the upper Palouse River Basin, including an economic appraisal. This early or preliminary work suggested a single-purpose project on the Palouse River with municipal and industrial use of water in the Pullman-Moscow area as the major beneficiary. Since the measurement of the benefits of a reservoir on the Palouse River which could be applied to a municipal water supply is determined by the least costly alternative, additional water sources outside the Palouse drainage were also investigated. Later revisions to the 1968 study included multi-purpose benefits of the Palouse River sites.

Population and water demand projections were prepared indicating a supplemental supply of 5 billion gallons per year will be required in the year 2020, in addition to a sustained yield of 1 billion gallons per year from the existing wells. The report assumed that sufficient storage will exist within the distribution system for daily peak requirements.

The following five alternatives were investigated and reviewed by the Army Corps of Engineers.

1. A pumped intake on the Snake River near Wawawai which would serve the City of Pullman through a 24-inch pipeline. A booster station would then be required at Pullman to serve the City of Moscow through an 18-inch pipeline.
2. A single-purpose reservoir to be located on the North Fork of the Palouse River at Harvard with a capacity of 24,000 acre-feet. Regulated releases from this storage reservoir would be diverted near the state line and transmitted through a 24-inch pipeline to a point between Pullman and Moscow.
3. A single-purpose reservoir of 20,000 acre-feet to be located on the North Fork of the Palouse River immediately above Laird Park. Diversion and transmission would be the same as proposed for the Harvard site.

4. A dual-purpose reservoir to be located on the Potlatch River near Bovill with a 10,000 acre-foot capacity. A 24-inch transmission line would serve the City of Moscow from the reservoir and continue to Pullman with a 24-inch diameter supply line.
5. A well-field to be developed in the North Fork of the Palouse River ground water basin. Assuming that this ground water basin is capable of producing a sustained yield of 5 billion gallons per year, ten 1,000 gpm wells are proposed with ten miles of 18-inch transmission line serving the urban area.

Cost estimates of each of the above schemes were prepared and amortization calculated using federal financing at the current rate of 4 5/8% interest over a period of fifty years. Comparative costs for each of the five schemes estimate water from the Snake River at \$0.125/1,000 gal., Harvard at \$0.1406/1,000 gal., Laird at \$0.1342/1,000 gal., Potlatch River at \$0.159/1,000 gal. and the well-field at \$0.0824/1,000 gal. The above unit costs are based upon the water consumption projected for the year 2020 at 5.14 billion gallons per year.

A more detailed evaluation of this study is covered in a subsequent chapter. Multi-purpose projects on the Palouse River are discussed at some length.

REVIEW OF  
U. S. CORPS OF ENGINEERS PROJECT

GENERAL

The water resource development program proposed in previously described studies by the U. S. Corps of Engineers (23)(24) would yield benefits in the following areas of multiple use: (a) municipal and industrial supply, (b) recreation, (c) potential irrigation, (d) flood control, (e) water quality control, and (f) downstream fish propagation. A proper review of the past feasibility studies would necessarily need to cover all of these areas. However, since the primary objective of this report is to examine single-purpose water supply projects, only a brief review will be made of other water uses with greater attention to the M & I allocation plans and facilities. USCE studies to date have been directed at development of the North Fork Palouse basin with alternatives found in other areas.

The reservoir capacities at potential Palouse River sites were optimized based on the needs of the above potential uses estimated in earlier work. In general, areas of both Idaho and Washington were involved. This indicated the highest excess benefit to be for reservoir sites near Harvard and Laird for gross storage volumes of 70,000 acre-feet at Laird and 104,000 acre-feet at Harvard. For these sizes, approximately 20-35% of the annual yield would be utilized for M & I use in the Pullman-Moscow area by the year 2020, with allowance for demands as shown in the following table, Table 5-1.

Annual costs of the dam-storage reservoir alone contain some confusion as reported. While revisions have apparently occurred during the Corps' studies, some values are reported for a 100-year project, others for a 50-year project. It is important to note that capitalized annual costs of treatment and terminal storage facilities have not been included. Also, raw water cost, delivered to Pullman-Moscow, is based on the full contract use or 2020 demand.



TABLE 5-1  
PALOUSE STORAGE SITES

|                       | <u>Harvard<br/>Site</u> | <u>Laird<br/>Site</u> |
|-----------------------|-------------------------|-----------------------|
| Gross Storage, AF     | 104,000                 | 70,000                |
| Annual Yield, AF      | 95,000                  | 54,000                |
| M & I Use, AF         | 18,200                  | 18,200                |
| Irrigation Use, AF    | 70,700                  | 27,500                |
| Benefit Cost Ratio    | 2.2                     | 1.8                   |
| Total Annual Cost, \$ | 940,000                 | 560,000               |
| M & I Annual Cost, \$ | 72,000                  | 72,000                |

#### PUMPING AND TRANSMISSION FACILITIES

Both alternates proposed by the Corps maintain the least costly alternate of delivering M & I water is through regulated release to the North Fork and pumping from a river intake near the state line or the town of Palouse, elevation 2,440 msl. The transmission line would follow the general route of the Great Northern Railroad right-of-way to Fallon rising some 325 feet with the pipeline then splitting to both Pullman and Moscow city limits. It is assumed that intermediate or terminal storage would be located at the terminus of each line. The USCE reports do not indicate whether raw or treated water would be pumped, but that the amount would be equal to the average daily demand for the ultimate design year. Our analyses indicate that if adequate terminal storage were provided, this capacity would prove satisfactory but the selection of pipeline sizes would differ because of higher demands. For economic and maintenance reasons, pumping of treated water is also preferred. A summary of the costs of the Corps' participation is presented in the following table, Table 5-2.

TABLE 5-2  
SUMMARY OF USCE  
ANNUAL COSTS FOR M & I USE

|                                      | <u>Size</u> | <u>2020 Annual Costs</u> |
|--------------------------------------|-------------|--------------------------|
| Raw Water Storage<br>(Multi-Purpose) | 70,000 AF   |                          |
| Raw Water Costs                      | 18,200 AF   | \$ 72,000                |
| Water Treatment Facility             | NA          |                          |
| Water Treatment O & M                | 14 mgd      | \$231,000                |
| Transmission Costs<br>(Incl. O & M)  | 24-inch     | \$320,000                |
| Terminal Storage Facility            | NA          |                          |
| TOTAL                                |             | \$623,000                |
| Cost/mg (2020)                       |             | \$ 118                   |

Further evaluation of the USCE costs indicate power or energy costs, placed at 3 mils/KWH, may be low for the proposed application. Because of the high demand charge to total use requirements, it is doubtful that millage rates will approach the 3 mils employed. Unless a special rate structure can be negotiated, charges can be expected to be closer to 5 mils. In addition, annual costs for water treatment, based on experience and available data for Northwest water treatment plants and the expected raw water quality, are expected to run \$0.02 to \$0.04/1,000 gal. treated above the costs employed in the USCE estimates. Such costs are for treatment of stored water. Regulated river flow would be higher by approximately \$0.01/1,000 gal. because of silt removal requirements.

## EFFECT OF REGULATED RELEASE

The Palouse River Basin above Palouse is spotted with agricultural development, dairy and beef cattle pasturing areas, and low density urban community development. Stream quality undergoes a significant change from above Harvard to Palouse. Examination of coliform levels, nitrates or total organic carbon content indicates three to four-fold increases. Low stream velocities, high nutrient loadings, and poor channel conditions can be blamed for such water quality degradation. Evidence to date indicates an extremely marginal quality for raw water if withdrawn near Palouse, with present stream conditions. While there is a need for better data, the quality is expected to remain considerably improved above the developed areas or in the reach near Harvard or Princeton. The limited data for the Palouse at Princeton indicates a satisfactory raw water quality. A comparison of desired raw water quality to measured conditions was given in Table 3-3. To meet the desired water quality requirements, either the intake and facilities have to be economically optimized for additional treatment costs versus site location, or stream velocities, pollution control measures and channel improvements are required. Sizing of either the Harvard or Laird projects for multiple use should accomplish provision of adequate minimum flows for dilution and flushing. For example, for a 54,000 AF annual yield at the Laird reservoir, a regulated flow near 65 cfs could be obtained with releases for both downstream irrigation and water supply uses but with substantial drawdown and possible loss of recreational benefit.

## CONCLUSIONS

The studies undertaken by the Corps of Engineers provide the best analysis of potential water resource development on the North Fork of the Palouse to date. However, unless the project as proposed can be more closely scaled for M & I use and made available within a time frame according to community needs, economic justification alone is doubtful. The analysis was also incomplete as to costs and physical plant requirements. It is concluded that the following revisions would be necessary in order to proceed with the program:

1. The dam-storage reservoir would have to be resized for a first-stage single-purpose use. This would eliminate consideration of the Harvard site and place all effort on a two-stage development of an optimal facility at the Laird site.
2. In order to reduce the costs of treatment and improve treated water quality, as well as esthetic conditions, withdrawals would require regulated river flow or that the intake and treatment site be moved above the developed region of the basin.
3. Consideration should be limited to pumping of treated water only to optimize pipeline and pumping plant sizing and operational costs.
4. Further investigations should be requested for USCE evaluation of scheduling, eligible phases for financing, and multi-stage reservoir construction.
5. Consideration could be given to a temporary reservoir site further upstream, possibly Poorman Creek, to provide approximately ten year's requirements and allow time for the USCE multi-purpose project to be approved, designed and constructed. This requires, however, commitment to the Palouse Basin source of supply.

## ALTERNATE COMPARISON CRITERIA

### GENERAL

To obtain comparative evaluation of the different sources of water supply, a preliminary engineering design and cost estimate for each alternate was required. This preliminary engineering on each of the projects further implied the need for common design criteria which would permit an optimum design of each particular alternate, yet yield a common basis for relative comparison.

The following discussion develops the design criteria used for this report. The discussion also outlines the application of the design criteria to the major components of the physical facilities and its basis for unit costs used to estimate the project costs. The discussion additionally outlines the methods used to expand both the estimated construction cost and the annual operating costs into an economic comparison of alternate plans.

### FLOW REQUIREMENTS

A prerequisite to the preliminary engineering and cost estimation of any alternate is the determination of the flow requirements to be accommodated by that particular facility. The first attempt to design and estimate the cost of each alternate assumed that the water treatment plant and conveyance facilities would be capable of supplying the total peak daily demand at all times, thus eliminating the need for any sustained use of the existing wells. See Table 2-6. The cost of accommodating this flow requirement was considered excessive, indicating a definite need for the consideration of conjunctive use of the existing wells. Consequently, alternative projects were redesigned and re-estimated with the assumption that the maximum capacity of the existing wells could be used for peaking requirements and lowering the capacity of long distance conveyance systems. Although this reduced demand from the surface supplies required less physical plant, the estimated costs of these facilities were still considered excessive. Therefore,

flow requirements were once again reduced in magnitude until the water treatment plants and conveyance facilities would be capable of supplying sufficient water to meet the projected average daily demand at all times, with peak demands met by conjunctive use of existing wells and terminal storage.



#### CONJUNCTIVE USE PLAN

The purpose of this analysis, as discussed in earlier sections, was to more economically employ all available sources, notably existing wells, storage, and waste water reuse with the potential surface supply. Existing well data indicates a total availability in capacity of about 25.5 mgd, excluding poorer quality wells. Natural recovery conditions of the aquifer are presently unknown, however, such a withdrawal magnitude would not be expected to occur more than two or three times a year and should significantly relax demands on ground water supplies. Less than 300 AF would be pumped in 1985 and only about 1,000 AF in 2020 compared to over 8,000 AF at present.

The reuse of waste water appears feasible, at least for irrigation purposes, for effluent from the Moscow sewage treatment plant. Golf courses, play field areas, and croplands could potentially utilize about 1 mgd during peak periods and thus offset demands on the potable supply system. This water would be used primarily by the University of Idaho.

A typical plan for conjunctive use of potential supply sources has been outlined for average and peak day conditions over the design period and presented in Figure VI-1. Flexibility is readily apparent in project staging, use of peak production capacities and demand on storage of treated water. Examination of the peak day demand curve indicates insufficient capacity of the present system by 1973.

Sufficient storage was assumed to be available in the local systems, presently about 12 mg, to handle peak hourly demands and fire demand. Final determination of future requirements for local storage would depend on a more detailed study of the distribution systems utilizing the demands projected by this report but beyond its scope of study.



- PEAK TREATMENT CAPACITY
- NOMINAL TREATMENT CAPACITY
- FROM STORAGE
- FROM EXISTING WELLS
- WATER REUSE

**TYPICAL  
CONJUNCTIVE USE PLAN**

FIGURE VI-1

## FLOW CRITERIA

The nominal design capacity of each alternate was essentially the same but the physical differences between the alternates indicated that the most economical design would undoubtedly differ for each alternate. It was therefore imperative that a common criteria for the rate of ultimate water delivery be developed which would permit variation in the design capacity of the pipelines, the pumping plant, and the quantity of terminal storage. Such criteria would necessarily permit both the optimum design for each alternate, and still allow a relative comparison between all alternates. The delivery criteria selected to satisfy these conditions stipulated that the combined capacity of all sources of water supply, (including the surface supply developed, the existing wells and the water reuse where applicable) combined with the total quantity released from terminal storage would supply three consecutive days of peak daily demand (Table 2-6) at any given time. Development and cost estimation of the affected components were consequently based upon this criteria.

## PIPELINES

Route selection for the transmission facilities required for each alternate were projected on topographical maps with special consideration given to the ease of right-of-way and to elevation limitations. Profiles for each of the alternates were then drafted from the topographical maps. A determination of the hydraulic grade lines was made and superimposed upon the profiles, thereby permitting analysis of the water pressures encountered and the selection of the strength of pipe required to withstand such pressures.

Unit costs for each of the various combinations of pipe sizes and weights required were developed for common use on all projects. The basis for these unit costs was data received from various manufacturers of both reinforced concrete cylinder pipe and steel pipe. Allowances were made for installation, right-of-way, clearing, appurtenances, and special conditions such as railroad or highway crossings and canyons.



## TERMINAL STORAGE

The capacity of the terminal storage required for each particular project was dependent upon the optimum design as determined by the basic delivery criteria previously developed. However, for those alternates containing extremely complex transmission facilities, the required capacity of the terminal storage was increased to provide three consecutive days of average flow during emergency conditions. Due to the magnitude of all storage facilities herein proposed, the cost estimates are based on a design utilizing reinforced concrete covered storage structures.

The unit prices developed for terminal storage facilities were obtained from similar facilities which have been recently constructed in the Northwest. Allowances to these unit prices were made to account for such miscellaneous items as site acquisition, access, site preparation, chlorination, and telemetering.

## PUMPING PLANTS

The capacity of the pumping plants for each particular alternate were also individually selected based upon the common delivery criteria.

Cost estimates of the pumping plants were derived from material provided by the U. S. Bureau of Reclamation (18). The design life of the pumps and the prime movers were estimated to be not more than twenty-five years or reflect a total replacement of these units with second stage construction.

Both high lift plants and conventional booster stations were incorporated in various alternative plans. A typical layout of a high lift pumping plant has been shown in Figure VI-2.

Cost of operation and maintenance of the pumping plants was obtained from a paper presented in the Irrigation and Drainage Journal of ASCE, (3). Determination of the costs by this procedure made allowance for the variables of flow, head, seasonal operation and local wage rates.

## STORAGE RESERVOIRS

For those alternates requiring impoundment of streams where the total runoff might be considered marginal, the storage capacity provided was 1.5 times greater than the total water demand for any particular year. Where the stream flow was sufficient to substantially augment the supply in storage, the required capacity of the reservoir equaled the net annual water demand for any particular year.


Cost estimates of the required storage reservoirs were derived from actual construction costs encountered by this firm and the U. S. Army Corps of Engineers data and estimates for regional reservoir projects.

## WATER TREATMENT


As previously indicated, the nominal capacity of proposed water treatment plants was sufficient to provide the projected average daily flow at any period of time. To account for maintenance, down time, backwashing, and some peaking capability, the actual sustained yield of filtration plants proposed exceeds the nominal capacity by a factor of 1.3. In addition, as shown in Figure VI-3, optional use of pre-sedimentation and seasonal use of carbon addition are proposed, depending on raw water conditions.

Cost estimation of water treatment plants was based upon expenditures experienced in the construction of similar facilities throughout the Northwest. The variable costs incurred for access, additional chemical treatment, pre-sedimentation, intake structures and clearwell storage were given due consideration where applicable. Additional consideration was given to the design life of the water treatment plant mechanical equipment by providing a replacement cost equal to sixty per cent of the original construction cost in the proposed expansion stage.

Operation, maintenance and chemical costs for individual treatment plants were obtained from records taken from existing water treatment plants with allowances for the degree of treatment provided and the size of the plant.



SECTION



PLAN

TYPICAL HIGH LIFT PLANT (WAWAWAI)

FIGURE VI-2



## POWER


Special consideration was given to the determination of power costs. Rate schedules obtained from Washington Water Power Company were used as a basis for calculating such power costs. Anticipated monthly power costs were calculated for various combinations of pumping head and flow. Examination of these calculated costs revealed that a power cost of \$0.005/kwh could be used throughout the study without appreciable error.

## ECONOMIC COMPARISON

Once the construction costs for the physical components, such as pipelines, pumping plants, water treatment plants, storage reservoirs, dams and pipeline appurtenances, were established, a relative comparison between the cost of any two or more alternate schemes was possible. Such economical comparison of each alternate was accomplished by placing all costs on a present worth basis to the year 1975. Since the initial construction costs were anticipated in the year 1975, the present worth of such initial construction equaled the estimated cost. Plant expansion and replacement of mechanical facilities in the pumping stations and water treatment plants estimated and planned to be accomplished in later years were capitalized as to present worth in the year 1975, thereby becoming equivalent to the initial construction costs.

All annual costs were estimated for both the year 1975 and for the year 2020. It was then assumed that the annual increase of these costs would conform to a gradient series analysis and that the present worth of the total amount of each annual cost would be calculated in accordance with the economic procedures developed for such cases. The present worth of the gradient series of annual costs was also capitalized to the year 1975 to maintain consistency.

As the above procedure placed the initial construction costs, the future construction costs, and the annual costs on a par value, the sum of those three values was then used as a basis of economic comparison between all alternate plans proposed.



TYPICAL WATER TREATMENT PLANT  
FLOW SHEET

FIGURE VI-3

## ALTERNATIVE PLANS OF WATER SUPPLY

### GENERAL

Preceding chapters of this report have been devoted to a description of the available surface water sources and drainage basins of the Pullman-Moscow region, the benefits and qualities of these sources, and previously proposed development schemes. Factors affecting water demand have been reviewed and future needs established. Additionally, unit design factors and general design criteria have been developed for storage and transmission facilities, treatment works and pumping plants and finally, unit and other costs have been established for the purpose of estimating construction costs, present worth of future staged construction, operation and maintenance, and amortization of all proposed construction.

Information in this chapter deals primarily with the development of several alternative plans selected as being the most feasible from the standpoint of engineering and construction feasibility, production of a high quality potable water supply, and practical facilities operation. The chapter also provides greater details as to recommendations of staged construction, specific design conditions and project costs. Complete financial plans for the most favorable alternates are presented in Chapter 8. The basic purpose of the work summarized in this chapter was to review all possible alternatives to at least a reconnaissance level to insure selection of the most adequate and economical surface water supply development for the Pullman-Moscow area.

The water supply planning is based primarily on serving the study area as defined earlier in the report. In the case of specific alternates, it is possible to include other communities in future planning. For example, alternates involving the North Fork of the Palouse River Basin could serve the communities of Potlatch, Palouse and Onaway, some of which expressed an interest in the future regional planning for water supply. Similarly, the community of Troy could also be included in plans for the Troy Watershed or the Potlatch River.

With the Snake River Project, it is doubtful that service to other communities would be possible without additional major transmission facilities construction. Several potential water supply sources received rather thorough review with reconnaissance level development and layout. Those included were the following:

1. Construction of a pumped intake and treatment of water from the Snake River above the Lower Granite Dam.
2. Construction of a storage facility on the North Fork of the Palouse River near Laird with treatment and pumping facilities at Princeton.
3. Development of a series of dams and reservoirs in the Troy/Moscow Mountain area with treatment facilities near Helmer.
4. Construction of a storage facility on the East Fork of the Potlatch River with treatment and pumping facilities near Helmer.
5. Construction of a pumped intake and treatment of water from the North Fork of the Clearwater River above the Dworshak Dam.
6. Construction of a storage facility on the North Fork of the Palouse River near Laird with treatment and pumping facilities at Palouse and following a route previously proposed by the Corps of Engineers.

General routes and locations of the proposed facilities, including pumping plants, water treatment plants, and damsite/reservoirs are presented in two location maps, Figures 7.1 and 7.2. Details as to each alternate are discussed in the specific sections of this chapter.

# ALTERNATIVE PLANS FOR WATER SUPPLY

## LOCATION MAP A



### LEGEND

- PUMPING PLANT
- ◈ WATER TREATMENT PLANT (1st stage)
- ◈ WATER TREATMENT PLANT (2nd stage)
- TERMINAL STORAGE RESERVOIR
- ▬ DAMSITE / RESERVOIR (1st stage)
- ▨ DAMSITE / RESERVOIR (2nd stage)

### Snake River Project

- 1 ● WAWAWAI P. P.
- 1 ◈ MacMURRAY CANYON W. T. P.
- 2 ● MacMURRAY CANYON P. P.
- 3 ● SUNSHINE P. P.
- 1 ■ TERMINAL RES.

### Troy Watershed Project

- 2 ■ BIG BEAR RES.
- 3 ■ SPRING VALLEY RES.
- 4 ▨ BIG MEADOW RES.
- 5 ■ LITTLE BEAR RES.
- 6 ▨ ROBINSON RES.
- 5 ● BIG BEAR P. P.
- 6 ● SPRING VALLEY P. P.
- 7 ● TROY P. P.
- 8 ● SOUTH PALOUSE P. P.
- 2 ■ TERMINAL RES.
- 3 ◈ TROY W. T. P.
- 4 ◈ SOUTH PALOUSE W. T. P.

### U.S.C.E. Palouse Basin Project

- 1 ■ LAIRD REGULATING RES.
- 2 ◈ PALOUSE W. T. P.
- 4 ● PALOUSE P. P.




FIGURE VII-1





# ALTERNATIVE PLANS FOR WATER SUPPLY

## LOCATION MAP B



### LEGEND

- PUMPING PLANT
- ◼ WATER TREATMENT PLANT
- TERMINAL STORAGE RESERVOIR
- ▬ DAMSITE / RESERVOIR

- |                               |                                 |
|-------------------------------|---------------------------------|
| <b>PALOUSE BASIN PROJECT</b>  | <b>CLEARWATER RIVER PROJECT</b> |
| 7 ■ LAIRD REGULATING RES.     | 12 ● DWORSHAK P. P.             |
| 5 ◼ PRINCETON W. T. P.        | 7 ◼ DWORSHAK W. T. P.           |
| 9 ● PRINCETON P. P.           | 13 ● MIDDLE POTLATCH P. P.      |
| 3 ■ STATELINE STORAGE RES.    | 5 ■ TOMER BUTTE TERMINAL RES.   |
| <b>POTLATCH RIVER PROJECT</b> |                                 |
| 8 ■ POTLATCH REGULATING RES.  |                                 |
| 6 ◼ POTLATCH W. T. P.         |                                 |
| 10 ● POTLATCH P. P.           |                                 |
| 11 ● SPRING VALLEY P. P.      |                                 |
| 4 ■ EAST MOSCOW TERMINAL RES. |                                 |




FIGURE VII-2

## SNAKE RIVER PROJECT

The Snake River Project would consist of a system of facilities to withdraw and treat water from the Snake River and deliver treated water to Pullman and Moscow. The project would have capacity to meet the estimated demand for water in year 2020, although some features would be constructed in two stages.

The main pumping plant would be located at Wawawai and would pump from the pool to be formed behind Lower Granite Dam. The treatment plant and additional pumping facilities would be located near Almota Creek, more than 1,800 vertical feet above the river. About twenty-five miles of pipeline would be required to deliver water to the project service area along the general route shown in Figure VII-1. Profiles of the proposed plan have also been presented in Plate Six found at the end of this chapter.

The estimated demand for water from the project described herein is given in Chapter II. The conjunctive use of ground water supply is anticipated to provide a peaking capacity of 26.5 mgd, including 1 mgd from reuse of treated waste water.

The main pumping plant of the project would be located at Wawawai on the Snake River about 11.3 miles southwest of Pullman and 1.7 miles upstream from the proposed Lower Granite Dam, in Whitman County.

The pumping plant would lift water from Lower Granite pool, whose normal water surface elevation is 738 feet above sea level, to elevation 2,570 feet at the top of the canyon near Almota Creek. At minimum pool elevation, the maximum static pump lift would be about 1,850 feet; during operation the maximum total dynamic head on the pumping plant would be about 1,950 feet when delivering the peak-day discharge in the design year.

The first stage plant employed is based on the following preliminary design assumptions:

1. Outdoor-type pumping plant.
2. Five pairs of pump and motor units, each pair consisting of two 7-stage vertical turbine pumps arranged in series; the rated capacity of each pump is 2,500 gpm at 1,000 feet total dynamic head.
3. Motors: 800 hp, 1,770 rpm vertical solid shaft induction motors; drip proof, weather protected enclosure; 3-phase, 60-cycle, 2,300-volt operation.
4. Surge suppression by means of an air chamber and control valves.
5. Suction pool level would be as controlled by Lower Granite Dam. If construction of the dam were delayed beyond start-up time for the pumping plant, an additional interim pumping facility and related discharge conduit would be required.
6. Plant capacity would be adequate to pump continuously at a rate of 16.0 mgd or 11,100 gpm. A second pumping plant would be required in about 1995, to operate in parallel with the first plant.

From Wawawai pumping plant to the water treatment plant, approximately 15,000 feet of 24-inch diameter pipeline would be required in the first stage. A parallel line of 20-inch diameter would be added in the second stage in 1995. The first 7,400 feet would be welded steel pipeline supported above ground on concrete piers, and anchored by large concrete blocks at about 1,000-foot intervals. This part of the pipeline includes the steep portion of the Snake River Canyon, with ground slopes of up to twenty-five percent.

The treatment plant would be located near the head of MacMurray Canyon, about one-half mile from Almota Creek. Ground elevation is about 2,570 feet above sea level in the area around the plant site.

The nominal capacity of the first stage treatment plant would be 15 mgd. It would have the capability of delivering about 20 mg on days of peak demand. The plant would provide flocculation and sedimentation, filtration and chlorination. Based on the projected water demand, a second stage treatment plant would be required in year 2000.

From the MacMurray water treatment plant, treated water would be delivered to Pullman and Moscow through a system of transmission lines and pumping plants. Both the Sunshine Creek pumping plant (booster station) located about 3.5 miles southeast of Pullman and the MacMurray plant adjacent to the water treatment plant would be expanded in about 1995.

The transmission system would be designed to deliver water at a rate to meet peak day demand in conjunction with the existing well capacity and about 5 mgd from terminal storage. Transmission lines in the present plan would be adequate until about 1995, at which time a parallel 20-inch pipeline would be constructed. Branch lines would have sufficient initial capacity to meet 2020 demand. From the treatment plant, the transmission line would be 24-inch diameter all the way to the terminal reservoir, some 16 miles. A branch line consisting of about 6,000 feet of 24-inch pipeline would extend into Pullman, and about 6,300 feet of 20-inch pipe to the WSU campus.

The main 24-inch transmission line would continue past the Sunshine Creek pumping plant site to the terminal reservoir about two miles south of Moscow. From the reservoir, a 20-inch diameter line would extend about 14,000 feet into Moscow. From this line, a branch of 16-inch diameter would extend to the University of Idaho campus. Under peak flow conditions, the transmission system would deliver water at the pressure gradient elevations given below to various locations.

|                   |            |
|-------------------|------------|
| 1. Pullman (city) | 2,662 feet |
| 2. WSU            | 2,650 feet |
| 3. U of Idaho     | 2,745 feet |
| 4. Moscow (city)  | 2,670 feet |

In case of a power outage, Pullman and WSU would be supplied by reverse flow from the terminal reservoir. Pipelines have been planned generally to traverse cross-country over rolling hills and farmland to hold the mileage of pipeline as low as possible.

A convenient site for a terminal reservoir has been selected from consideration of the required elevation and closest possible location to the service area. The site is a ridge located about two miles south and slightly west from Moscow, where the ground elevation is about 2,880 feet above mean sea level.

The cost estimates are based on the use of prestressed concrete reservoirs of 30-foot nominal height. Terminal storage capacity is predicated on the provision of three consecutive peak day requirements in the design year, without draining on existing storage in the service areas. The existing capacity is estimated to be 12.4 mg. To meet the 1995 requirement under this criterion, a reservoir of 16 mg would be constructed. A second reservoir of about 8 mg would be added in 1995 to meet the full requirement in 2020.

Other factors pertaining to the Snake River project which warrant consideration are noted below. Evaluation of these factors in terms of economic cost or benefit has not been made.

1. The plan as formulated presumes that Lower Granite Dam and Reservoir on the Snake River will be in existence by the time project water deliveries are planned(1975+). If the construction of the dam proceeds as now scheduled, this condition will be met.
2. The cost of electrical energy for pumping represents a substantial part of the capitalized project cost over the 45-year period of analysis. This estimate is based on a rate of 5 mills per kwh. Possibly a lower rate could be negotiated, resulting in considerable reduction of capitalized project cost.
3. The unique feature of the Snake River project is the high-head pumping plant which would be located at Wawawai. The total dynamic head of about 1,950 feet which the plant would develop, is exceeded by few pumping installations in the United States.

Engineering research and development during the past six years has been undertaken for the Tehachapi pumping plant of the State of California water project. The lift at Tehachapi is almost identical to that required at Wawawai, although the design flow at Tehachapi is 4,100 cfs compared to about 46 cfs at Wawawai. The Tehachapi plant is currently under construction.

A two-lift system for the Wawawai plant does not appear practical due to the topography of the Snake River Canyon, but should not be ruled out until detailed engineering studies are made of both alternative systems. The canyon wall does not appear to contain an ideal site for locating a second-lift plant.

The capital cost of the first stage of construction is estimated to be \$9,014,000 and the total capitalized cost of all project expenditures during the period 1975 to 2020 is estimated to be \$17,712,000. The approximate annual cost of the first year of project operation (1975) including amortization at seven per cent for thirty years is \$1,143,400. The resulting unit cost of water in 1975 would be \$318 per million gallons. Capital costs for each required stage are shown in Table 7-1.

#### PALOUSE RIVER BASIN PROJECT

Under this plan, the Pullman-Moscow area would be served by a major water supply development of the North Fork of the Palouse River with a damsite/reservoir at Laird and an intake above Princeton in Idaho. A water treatment plant and pumping facility, located near Princeton, would provide the treated water which would be conveyed by a 30-inch transmission line to terminal storage near Viola. Gravity lines would feed the major intermediate level distribution storage reservoirs in Moscow, Pullman and Washington State University. The University of Idaho would be served by a booster station joined from the Moscow distribution system. Water would also be available for the towns of Potlatch, Onaway and other small communities in the Palouse River Basin, either treated or untreated on a contractual basis.

TABLE 7-1  
SNAKE RIVER ALTERNATE  
PROJECT COST SUMMARY

|                                   |                   |                   |
|-----------------------------------|-------------------|-------------------|
| First Stage (1975) Capital Costs  |                   |                   |
| Transmission Line & Appurtenances |                   | \$ 2,783,800      |
| Terminal Reservoir                |                   | 743,800           |
| Wawawai Pumping Plant             |                   | 1,407,700         |
| MacMurray Pumping Plant           |                   | 380,800           |
| Sunshine Pumping Plant            |                   | 79,200            |
| Water Treatment Plant             |                   | <u>1,538,500</u>  |
|                                   | Subtotal          | \$ 6,933,800      |
|                                   | 18% Contingencies | 1,248,100         |
|                                   | 12% Engineering   | <u>832,100</u>    |
|                                   | TOTAL             | \$ 9,014,000      |
|                                   |                   |                   |
| Second Stage (1995) Capital Costs |                   |                   |
| Transmission Line & Appurtenances |                   | \$ 1,800,800      |
| Terminal Reservoir                |                   | 412,300           |
| Wawawai Pumping Plant             |                   | 1,123,000         |
| MacMurray Pumping Plant           |                   | 280,800           |
| Sunshine Pumping Plant            |                   | <u>53,800</u>     |
|                                   | Subtotal          | \$ 3,670,700      |
|                                   | 18% Contingencies | 660,700           |
|                                   | 12% Engineering   | <u>440,600</u>    |
|                                   | TOTAL             | \$ 4,772,000      |
|                                   |                   |                   |
| Third Stage (2000) Capital Costs  |                   |                   |
| Water Treatment Plant             |                   | <u>\$ 689,200</u> |
|                                   | Subtotal          | \$ 689,200        |
|                                   | 18% Contingencies | 124,100           |
|                                   | 12% Engineering   | <u>82,700</u>     |
|                                   | TOTAL             | \$ 896,000        |

1975 ANNUAL COST

|   |       |                |
|---|-------|----------------|
| Amortization of First Stage Capital Costs   |       |                |
| (30 years at 7% per annum)                  |       | \$ 726,400     |
| Operation and Maintenance of Physical Plant |       | 250,000        |
| Power                                       |       | <u>167,000</u> |
|   | TOTAL | \$ 1,143,400   |

The plan presented would provide the demands in two stages through the year 2020. Initial stage construction in 1975 would include a 15,000 acre-feet storage reservoir at the Laird site with gravity release and downstream withdrawal at an intake near the water treatment plant. Early use of the stored water would be for primarily M & I use with additional volume for downstream water rights and fish propagation. Recreational use would also be possible during the early years of the design period but become restricted as seasonal drawdowns increase.

The first stage of the water treatment plant would provide a nominal capacity of 15 mgd with a peak production capacity of approximately 20 mgd. The plant would incorporate conventional alum treatment and filtration but be preceded by siltation or presedimentation basins during spring runoff periods when high silt loads can be expected in the Palouse. Such basins could be of earth construction and also act as sludge disposal facilities. An additional 5 mgd of nominal capacity would be required as part of the second stage construction or about year 2000. Peak capacity would make available about 6 mgd for local use by nearby communities.

Pumping plant and storage facilities would also be staged with additions required in 1990-2000. Pipeline capacities for ultimate needs would be provided in the first stage.

The initial construction cost, including engineering and contingencies, is \$14,599,500, with a first year annual cost of \$1,456,900. Total capitalized cost, including the present worth of future operation expenses and second stage construction is \$19,970,600. Estimated staged construction costs and first year annual costs are summarized in Table 7-2.

The proposed Palouse project offers a good quality water supply with further flexibility to increase the storage capacity to 70,000 acre-feet to provide multiple use and if required, a raw water gravity pipeline from the dam to the treatment site.



TABLE 7-2  
PALOUSE BASIN ALTERNATE  
PROJECT COST SUMMARY

|                                   |                   |                  |
|-----------------------------------|-------------------|------------------|
| First Stage (1975) Capital Costs  |                   |                  |
| Transmission Line & Appurtenances |                   | \$ 4,193,500     |
| Stateline Storage Reservoir       |                   | 554,500          |
| Princeton Pumping Plant           |                   | 497,500          |
| Laird Regulating Reservoir        |                   | 3,810,000        |
| Water Treatment Plant             |                   | 1,675,000        |
| Palouse Intake & Diversion Dam    |                   | <u>500,000</u>   |
|                                   | Subtotal          | \$11,230,500     |
|                                   | 18% Contingencies | 2,021,500        |
|                                   | 12% Engineering   | <u>1,347,500</u> |
|                                   | TOTAL             | \$14,599,500     |

|                                   |                   |                   |
|-----------------------------------|-------------------|-------------------|
| Second Stage (1990) Capital Costs |                   |                   |
| Princeton Pumping Plant           |                   | <u>\$ 265,500</u> |
|                                   | Subtotal          | \$ 265,500        |
|                                   | 18% Contingencies | 47,800            |
|                                   | 12% Engineering   | <u>31,900</u>     |
|                                   | TOTAL             | \$ 345,200        |

|                                  |                   |                  |
|----------------------------------|-------------------|------------------|
| Third Stage (2000) Capital Costs |                   |                  |
| Stateline Storage Reservoir      |                   | \$ 970,000       |
| Water Treatment Plant            |                   | 750,000          |
| Laird Gravity Line               |                   | <u>1,404,800</u> |
|                                  | Subtotal          | \$ 3,124,800     |
|                                  | 18% Contingencies | 562,500          |
|                                  | 12% Engineering   | <u>375,000</u>   |
|                                  | TOTAL             | \$ 4,062,300     |

1975 ANNUAL COSTS

|   |       |               |
|---|-------|---------------|
| Amortization of First Stage Capital Costs<br>(30 years at 7% per annum) |       | \$ 1,176,000  |
| Operation and Maintenance of Physical Plant                             |       | 234,500       |
| Power   |       | <u>46,400</u> |
|   | TOTAL | \$ 1,456,900  |

Possible participation of Federal agencies should still be considered in the storage reservoir if negotiations can determine early construction (1975) and approval of a single purpose project, or single purpose project for the first stage only, with subsequent elevation of the dam to incorporate future multiple use. Costs of the raised dam have not been estimated but would be similar to estimates in the USCE Palouse Basin alternate.

Profiles for the proposed route of the Palouse alternate are shown in Plates One and Two (A-1 through A-4) and follow the general route presented in the general location maps. Project construction lies primarily in the State of Idaho.

#### TROY WATERSHED PROJECT

The Troy Watershed Project proposed would consist of a system of facilities to conserve, treat, and deliver municipal water to Moscow and Pullman, with water also available for the town of Troy. The project envisioned is independent of the RC & D proposal prepared by the Troy Watershed Development Committee and the material presented is the least costly alternative for development of this source. Construction of the facilities would be staged over the project period to meet the projected water demand in the most economical way. The plan as presented herein would have capacity to provide the water required in the year 2020. The project would include five dams, two water treatment plants, five pumping plants, a terminal storage reservoir, and approximately thirty-three miles of pipeline.

The plan as formulated would include two dams in the first stage and three additional dams constructed singly as required. The first stage dams are the Little Bear Dam on the West Fork of Little Bear Creek, about two miles upstream from Troy, and the Big Bear on the West Fork of Big Bear Creek, about seven miles northeast of Troy. The estimated firm yield of these two proposed reservoirs is 11,500 acre-feet per year. The future dams are Spring Valley (required in 1985) on the creek of the same name, located about two miles northeast of Troy, Big Meadow on Big Meadow Creek (required in 1995) and a new Robinson Dam on the South Fork of the Palouse River (required 2016).

A detailed study of the hydrology of the Troy watershed was not made but accepted as sufficiently accurate such data as the mean annual runoff for each site as estimated by others (17). For this project it was assumed that a firm annual yield of eighty per cent of the mean annual runoff (MAR) could be developed with a storage reservoir with capacity of about 1.5-1.6 times the MAR. In addition to the active storage capacity, a sediment pool would be provided which is included in the gross reservoir capacities.

Physical data pertaining to the five dams and reservoirs is contained in Table 7-3. For the present study, all dams and reservoirs are planned for a single purpose of municipal water supply use. There may be incidental recreation or flood control benefits resulting from the reservoirs but no attempt has been made herein to evaluate such benefits. Reservoir operation would have to be strictly in accordance with the requirements for providing a reliable water supply and could not be modified to embrace other goals unless larger reservoirs are provided. All dams were assumed to be earth-fill type embankment dams with shaft spillways.

Transmission of water from the reservoirs to treatment plants and thence to Moscow and Pullman terminal storage would require about 33 miles of pipeline. The sizes of these lines would range from 16-inch to 27-inch diameter. In 1995, an additional 16-inch line would be required to parallel the original 24-inch in the reach from Moscow to Pullman. The general route profile is presented in the plates following this chapter.

The 1975 proposed system would begin at Big Bear Creek with stored water from both Big Bear and Little Bear reservoirs released to the streams and subsequently diverted and pumped to the Troy water treatment plant. Treated water would be pumped through the Troy transmission line generally following State Highway 8. Treated water would also be available to serve Troy, but would require an additional short branch line, not included in this plan as presently estimated. The flow of the Troy transmission line would be boosted by pumping near the point where the line would cross South Fork Palouse River to provide sufficient pressure for delivery to Moscow, Pullman, and the offline terminal reservoir. A small pumping installation would

TABLE 7-3  
 PHYSICAL DATA ON PROPOSED DAMS AND RESERVOIRS

| <u>Name of Reservoir</u> | <u>Year of Construction</u> | <u>Sec.</u>       | <u>Township</u> | <u>Range</u> | <u>Maximum Height of Dam feet</u> | <u>Normal Pool Elevation feet, MSL</u> | <u>Active Storage Capacity Normal Pool Acre-Feet</u> | <u>Estimated Firm Annual Yield Acre-Feet</u> |
|--------------------------|-----------------------------|-------------------|-----------------|--------------|-----------------------------------|--|--|--|
| Big Meadow               | 1995                        | NW 1/4<br>Sec. 6  | 39N             | 3W           | 90                                | 2,730                                  | 7,260  | 3,500  |
| Little Bear              | 1975                        | SW 1/4<br>Sec. 2  | 39N             | 4W           | 81                                | 2,681                                  | 9,900  | 5,000  |
| Robinson                 | 2016                        | W 1/2<br>Sec. 1   | 39N             | 5W           | 62                                | 2,732                                  | 4,250  | 2,100  |
| Big Bear                 | 1975                        | NW 1/4<br>Sec. 19 | 40N             | 2W           | 73                                | 2,764                                  | 12,800   | 6,500  |
| Spring Valley            | 1985                        | NE 1/4<br>Sec. 5  | 39N             | 3W           | 80                                | 2,710                                  | 6,000  | 3,000  |

VII-14

be required at Big Meadow Reservoir when this facility is added to the project. It would pump water over the reservoir rim at a low saddle and release it into a tributary of Little Bear Creek for subsequent diversion at the Troy water treatment plant. By about 2016, the proposed Robinson Reservoir would be required. A 14-inch pipeline from the dam to the second water treatment plant site on the South Fork is planned. Water from Robinson Reservoir, treated at this point, could then be pumped into the Troy transmission line.

The proposed Spring Valley Dam construction is projected for 1985. The yield from this reservoir would be pumped into the Big Bear pipeline, and thence to Troy and the service area.

The 1975 Big Bear pipeline plans require delivery of only the ultimate average-day rate flow from the two reservoirs which supply it. The peak-day increment in excess of the average-day flow could be met from the other reservoirs.

The pumping plants of the first stage are to be designed for the projected requirements in the year given as follows:

|                                  |      |
|----------------------------------|------|
| Big Bear Pumping Plant.....      | 2020 |
| South Palouse Pumping Plant..... | 1990 |
| Troy Pumping Plant.....          | 1995 |

Under maximum flow conditions, delivery pressure in Pullman would be at hydraulic gradient elevation of 2,662 feet, msl. In Moscow, pressure will be sufficient to fill the existing high tank at the University of Idaho (elevation 2,810 feet).

The terminal reservoir for treated water in the planned system is to be located on a north spur of Paradise Ridge near Moscow. The bottom elevation of the reservoir would be about 2,910 feet, msl. with overflow at about 2,940 feet.

To meet the requirement until the year 2012, an initial terminal storage capacity of 16 mg would be constructed. A second stage reservoir of about 14 mg would be added in 2012.

The plan requires one water treatment plant initially located near Troy. Ultimately, a small plant would be required to treat water from Robinson Reservoir. Nominal capacity would be about 18 mgd at the Troy plant and about 2 mgd at the South Palouse plant. Together they could deliver a peak demand of about 30 mgd.

There may be intangible costs or benefits worthy of consideration for this alternate project but for which no dollar value has been placed in the present study. Some intangibles are noted below.

1. The location of certain project features near Troy would make it feasible to deliver water to the town of Troy.
2. The complex of dams and reservoirs as planned have capacity only for municipal and industrial water supply. However, it may be feasible to enlarge the storage capacity to provide for flood water storage for protection of downstream areas. As a multiple purpose project, the cost for each purpose may decrease due to economies of scale.
3. Existing water rights have not been investigated. If such rights exist downstream from the reservoirs, it may be necessary to purchase the rights in order to operate the planned project.
4. Moderately high sediment yields are expected from the Troy watershed under existing conditions of cover and land use. Water treatment costs may be slightly higher during parts of the year than would be experienced with less turbid water. Sediment pools (dead storage) are provided in each reservoir with the capacities estimated to be adequate for at least fifty years under the conditions of sediment production now existing in the watershed.

The capital cost of the first stage of construction is estimated to be \$14,544,000, and the total capitalized cost of all project expenditures during the period 1975 to 2020 is estimated to be \$23,288,000. The approximate annual cost of the first year of project operation (1975) including amortization is estimated to be about \$1,435,100. This would result in a unit water cost of \$399 per million gallons of water produced. Staged construction costs have been summarized in Table 7-4.

TABLE 7-4  
TROY WATERSHED ALTERNATE  
CAPITAL COST SUMMARY

|                                   |                     |
|-----------------------------------|---------------------|
| First Stage (1975) Capital Costs  |                     |
| Transmission Line & Appurtenances | \$ 3,646,000        |
| Terminal Reservoir                | 750,000             |
| Big Bear Pumping Plant            | 113,000             |
| Troy Pumping Plant                | 273,000             |
| S. Palouse Pumping Plant          | 171,000             |
| Big Bear Reservoir                | 2,240,000           |
| Little Bear Reservoir             | 2,310,000           |
| Water Treatment Plant             | 1,685,000           |
| Subtotal                          | <u>\$11,188,000</u> |
| 18% Contingencies                 | 2,013,000           |
| 12% Engineering                   | 1,343,000           |
| TOTAL                             | <u>\$14,544,000</u> |

|  |                     |
|--|---------------------|
| Second Stage (1985-2000) Capital Costs |                     |
| Transmission Line & Appurtenances      | \$ 755,000          |
| Spring Valley Pumping Plant            | 42,000              |
| Troy Pumping Plant                     | 500,000             |
| S. Palouse Pumping Plant               | 231,000             |
| Spring Valley Reservoir                | 2,600,000           |
| Big Meadow Reservoir                   | 2,890,000           |
| Subtotal                               | <u>\$ 7,038,000</u> |
| 18% Contingencies                      | 1,266,000           |
| 12% Engineering                        | 845,000             |
| TOTAL                                  | <u>\$ 9,149,000</u> |

|                                       |                     |
|---------------------------------------|---------------------|
| Third Stage (2000-2020) Capital Costs |                     |
| Robinson Transmission Line            | \$ 158,000          |
| Robinson Reservoir                    | 2,850,000           |
| Terminal Reservoir                    | 645,000             |
| S. Palouse Pumping Plant              | 254,000             |
| S. Palouse Treatment Plant            | 378,000             |
| Subtotal                              | <u>\$ 4,285,000</u> |
| 18% Contingencies                     | 772,000             |
| 12% Engineering                       | 515,000             |
| TOTAL                                 | <u>\$ 5,572,000</u> |

1975 ANNUAL COSTS

|   |                     |
|---|---------------------|
| Amortization of First Stage Capital Costs<br>(30 years at 7% per annum) | \$ 1,172,000        |
| Operation and Maintenance of Physical Plant                             | 215,800             |
| Power   | 47,300              |
| TOTAL   | <u>\$ 1,435,100</u> |

## POTLATCH RIVER PROJECT

This alternative plan proposes diversion of water from the main Potlatch River at a point due south of Helmer, Idaho, and transmitting the water from that point to the communities of Pullman and Moscow. Augmented flow into the river is proposed by regulated releases from a storage reservoir to be constructed on the East Fork of the Potlatch River in the vicinity of Bovill, Idaho. The reservoir has a planned capacity of 22,000 acre-feet stored behind an earth-filled dam and a normal pool elevation near 3,000. The regulated release from this reservoir would be diverted by a gravity intake located at the point of diversion previously described.

Water treatment facilities are proposed to be located at the same site and fed directly by the gravity intake. The initial capacity of the water treatment plant is projected to be 15 mgd, a nominal capacity which would be sufficient until the year 2000. At this future date, the treatment plant is scheduled to be expanded to a nominal capacity of 20 mgd and capability of providing sufficient water until the year 2020.

The transmission facilities required to convey the water to the terminal storage site would follow the route shown in the general location map and require approximately twenty miles of pipeline. First stage construction of this transmission facility is proposed to be a 24-inch diameter pipe, providing sufficient capacity until the year 1995. In 1995, second stage construction is scheduled, specifying duplication of the original 24" diameter pipeline.

Two pumping plants would be required to lift the water to the site of terminal storage. The first, and largest plant, would be located at the point of diversion immediately adjacent to the water treatment plant. The total head provided by this initial pumping plant would be sufficient to convey the water approximately seventeen miles, at which point a booster station would be required to transmit the water the remaining distance to the site of terminal storage. The booster station is located at the intersection of the transmission line and Spring Valley Creek.



Terminal storage facilities are provided through three different construction stages. Initial construction in 1975 would call for a 25 mg facility which would be sufficient until the year 1980. The second stage of construction would take place in the year 1980 and would require a 11.3 mg facility whose capacity would be sufficient until the year 2000. The site selected for terminal storage is located on the ridge between the Palouse drainage and the Potlatch drainage, immediately north of the community of Joel, Idaho, at an elevation of 2,900 msl.

Additional stage construction is proposed for the transmission facility between the terminal storage site and the community of Moscow. The first stage of construction schedules a 30-inch diameter pipe, providing sufficient capacity until the year 1995, at which time an additional 30-inch diameter facility must be constructed to provide adequate capacity until the year 2020. The transmission facility beyond the point of delivery for the City of Moscow also projects construction of a 30-inch diameter pipe, however, the capacity of this facility as initially constructed should be sufficient until the year 2020.

The initial project cost of this plan is \$15,555,000. The first year operating costs are \$1,515,700, an amount which projects the cost of water during the first year to be \$421 per million gallons. The total capitalized cost of the project is calculated to be \$21,608,000. Staged construction costs for the Potlatch alternate are summarized in Table 7-5.

One major advantage of this alternate is the excellent water quality and water quantity expected from the source of supply. The protected watershed in the upper reaches of the Potlatch River produces a high quality of water of proven quantity. Another possible advantage is the possible enhancement to the fisheries on the mainstem of the Potlatch provided by the regulated release and augmented flow. It should be additionally noted that the routing of the transmission line would provide convenient service to the communities of Troy and Deary.

The obvious disadvantage of this scheme is the high cost, a factor which prohibits serious consideration of this alternate.

TABLE 7-5  
POTLATCH COST SUMMARY

|   |                   |                     |
|---|-------------------|---------------------|
| First Stage (1975) Capital Costs  |                   |                     |
| Transmission Line & Appurtenances                                       |                   | \$ 3,986,000        |
| Terminal Reservoir  |                   | 990,000             |
| Potlatch Pumping Plant  |                   | 453,500             |
| Spring Valley Pumping Plant   |                   | 355,000             |
| Regulating Reservoir  |                   | 4,120,000           |
| Water Treatment Plant   |                   | 1,710,000           |
| Water Treatment Plant Intake  |                   | 351,250             |
|   | Subtotal          | <u>\$11,965,750</u> |
|   | 18% Contingencies | 2,153,800           |
|   | 12% Engineering   | 1,435,900           |
|   | TOTAL             | <u>\$15,555,400</u> |
| Second Stage (1980) Capital Costs                                       |                   |                     |
| Terminal Reservoir  |                   | \$ 525,000          |
|   | Subtotal          | <u>\$ 525,000</u>   |
|   | 18% Contingencies | 94,500              |
|   | 12% Engineering   | 63,000              |
|   | TOTAL             | <u>\$ 682,500</u>   |
| Third Stage (1995) Capital Costs  |                   |                     |
| Transmission Line & Appurtenances                                       |                   | \$ 2,621,900        |
| Terminal Reservoir  |                   | 525,000             |
| Potlatch Pumping Plant  |                   | 90,000              |
| Spring Valley Pumping Plant   |                   | 70,000              |
| Water Treatment Plant   |                   | 1,396,000           |
|   | Subtotal          | <u>\$ 6,302,900</u> |
|   | 18% Contingencies | 1,134,500           |
|   | 12% Engineering   | 756,300             |
|   | TOTAL             | <u>\$ 8,193,700</u> |
| 1975 ANNUAL COST  |                   |                     |
| Amortization of First Stage Capital Costs<br>(30 years at 7% per annum) |                   | \$ 1,253,400        |
| Operation and Maintenance of Physical Plant                             |                   | 212,800             |
| Power   |                   | 49,500              |
|   | TOTAL             | <u>\$ 1,515,700</u> |

## CLEARWATER RIVER PROJECT

Another source of surface water studied was the backwater pool which will be formed upon completion of construction of Dworshak Dam on the North Fork of the Clearwater River. The plan proposes to pump water from the Dworshak Reservoir to a water treatment plant and then transmit the treated water to the communities of Pullman and Moscow.

Water would be taken from the reservoir through a pumped intake located at Dick's Creek. Due to an anticipated drawdown of 144 feet within this reservoir, a major intake facility would be necessary.

Approximately 31.5 miles of transmission line will be required between the pumped intake and the terminal storage facility. The pipeline is to be built in two stages; the first of which will accommodate the flows anticipated up to the year 1995, and the second providing the necessary additional capacity to accommodate flows until the year 2020. The first construction stage specifies construction of a pipeline 24-inches in diameter, and in 1995, the second stage of construction will require a similar 24-inch diameter conduit. Due to the varying topography along the transmission line route, portions of the pipeline will be constructed to withstand pressures up to 600 psi. However, approximately twenty miles of this facility would be subjected to pressures less than 100 psi.

The proposed water treatment facilities are to be located adjacent to the transmission line route approximately four miles west of the intake. The water treatment plant is designed to have a nominal capacity of 15 mgd and be sufficient until the year 2000. To accommodate the flows anticipated between 2000 and 2020, second stage construction in the year 2000 will require the capacity of the plant to be expanded for an additional flow of 5 mgd.

The pumping units at the intake will supply sufficient energy to transmit the water to the water treatment plant. Due to the magnitude of the head (1,680 feet) required for such transmission, these pumping units will be very complex and will require a considerable amount of electrical power. From the water treatment plant, gravity flow can

be achieved for approximately eighteen miles at which point an additional pumping station must be installed to lift the water into terminal storage. This proposed booster station should be located at the point where the transmission line crosses Little Bear Creek.

The required terminal storage facilities are identical to those described in the Potlatch Alternate, scheduling construction of 25 mg facility in the year 1975, a 11.3 mg facility in 1980, and an additional 11.3 facility in the year 2000. The storage facilities are planned to be constructed on Tomer Butte immediately southwest of Moscow at an elevation of 2,900 MSL.

The initial construction stage specified a 30-inch diameter transmission facility to be constructed between the terminal storage site and the city of Moscow. By the year 1995, the need for additional capacity will require a similar 30-inch diameter pipeline to be constructed. Initial construction of the transmission line beyond the city of Moscow specified continuation of the 30-inch diameter pipe, however, the capacity of this pipe will be sufficient until the year 2020.

The initial project cost for the Dworshak supply is estimated to be \$14,498,400. The operating costs anticipated during the first year total \$1,555,700, and would result in a consumption cost of \$432 per million gallons. The total capitalized cost for this alternate is \$23,334,000 as summarized in Table 7-6.

Although this source of supply would provide a superior quality of raw water from a virtually inexhaustible source of supply, the extensive length of the required transmission line results in a prohibitive cost for construction. Additionally, the high pressure encountered along the transmission line would likely require excessive maintenance.

#### USCE PALOUSE BASIN ALTERNATE

General interest in the water supply plan which had been proposed by the U. S. Corps of Engineers and which was reviewed in Chapter V has resulted in an analysis similar to those in preceding sections. A chief variation from previous alternative plans is that portions of the

TABLE 7-6  
CLEARWATER COST SUMMARY

|                                   |                   |                     |
|-----------------------------------|-------------------|---------------------|
| First Stage (1975) Capital Costs  |                   |                     |
| Transmission Line & Appurtenances |                   | \$ 5,700,700        |
| Terminal Reservoir                |                   | 990,000             |
| Dworshak Pumping Plant            |                   | 1,641,000           |
| Bear Creek Pumping Plant          |                   | 760,000             |
| Water Treatment Plant             |                   | 1,710,000           |
| Dworshak Intake                   |                   | 351,200             |
|                                   | Subtotal          | <u>\$11,152,900</u> |
|                                   | 18% Contingencies | 2,007,200           |
|                                   | 12% Engineering   | 1,338,300           |
|                                   | TOTAL             | <u>\$14,498,400</u> |

|                                   |                   |                   |
|-----------------------------------|-------------------|-------------------|
| Second Stage (1980) Capital Costs |                   |                   |
| Terminal Reservoir                |                   | \$ 525,000        |
|                                   | Subtotal          | <u>\$ 525,000</u> |
|                                   | 18% Contingencies | 94,500            |
|                                   | 12% Engineering   | 63,000            |
|                                   | TOTAL             | <u>\$ 682,500</u> |

|                                   |                   |                     |
|-----------------------------------|-------------------|---------------------|
| Third Stage (2000) Capital Costs  |                   |                     |
| Transmission Line & Appurtenances |                   | \$ 4,188,700        |
| Terminal Reservoir                |                   | 525,000             |
| Dworshak Pumping Plant            |                   | 350,000             |
| Bear Creek Pumping Plant          |                   | 160,000             |
| Water Treatment Plant             |                   | 1,396,000           |
|                                   | Subtotal          | <u>\$ 6,619,700</u> |
|                                   | 18% Contingencies | 1,191,500           |
|                                   | 12% Engineering   | 794,400             |
|                                   | TOTAL             | <u>\$ 9,505,600</u> |

1975 ANNUAL COST

|   |       |                     |
|---|-------|---------------------|
| Amortization of First Stage Capital Costs<br>(30 years at 7% per annum) |       | \$ 1,168,200        |
| Operation and Maintenance of Physical Plant                             |       | 220,500             |
| Power   |       | 167,000             |
|   | TOTAL | <u>\$ 1,555,700</u> |

project eligible for USCE participation would have independent design, construction and financing. Only facilities connected with treatment, storage and local distribution would be undertaken by the local communities. This condition influenced the structure of the system somewhat as will be shown later.

Optimum development of the Palouse River Basin, and particularly the Laird site, has been shown to be construction of a multi-purpose reservoir. By reasons of the multiple benefits and the economy of scale, M & I participation in a much larger reservoir than employed for the previous Palouse alternate could promote some savings in annual costs in addition to sizeable financing benefits, such as deferred principal payment and lower interest rates. The USCE scoping study (24) showed the benefit cost ratio to be in a potentially feasible project range for a 70,000 acre-feet reservoir. Based on water resource studies an annual yield near 54,000 acre-feet could be realized. Approximate dam height is 184 feet with a seasonal drawdown of about ten feet.

The project proposed is a redesign of the USCE concept based on the common design criteria of this study. Thus, transmission line sizes and pumping plant capacities differ from earlier reports. Pumping of treated water has been assumed with all terminal storage located within the city limits of both Pullman and Moscow.

With the location of a diversion dam and raw water intake just upstream from Palouse, conveyance facilities would follow the route of the Northern Pacific Railroad right-of-way some 16.5 miles to Pullman. A master metering station and beginning of a separate transmission line to Moscow would be just beyond Fallon. Transmission lines were designed for ultimate sizes of 30-inch and 24-inch which was found to be more economical than staging for this alternate.

A 15 mgd water treatment plant, identical to the proposed plant in the Palouse Alternate would be located at the point of diversion. A second stage addition of 5 mgd would be required by the year 2000.

The high lift pumping plant would pump in a single stage, 782 feet lift, an ultimate flow of 27.5 mgd. The flow would be supplemented by 6 mgd from storage and 26.5 mgd from existing wells and water reuse to meet the ultimate peak demand. Storage has also been staged with initial 1975 requirements being a 10 mg prestressed-concrete covered reservoir for Pullman and a 6 mg reservoir for Moscow. An additional 4 mg in the Moscow area would be necessary by 2000. Reservoir overflows would be adequate to serve the intermediate systems of both communities.

Profiles of this alternate, similar to other proposals, have been developed and presented in Plates Three and Four. Capital costs for the various stages proposed and the first year's annual cost are given in Table 7-7. Based on providing 3.6 billion gallons the first year, a unit cost near \$250 per million gallons can be expected.

First stage capital costs include those borne by the Corps of Engineers totaling \$8,776,000. Included is \$3,125,000 as the estimated M & I cost allocation. Actual reservoir cost may total \$11,000,000 for a 70,000 AF project.

## SUMMARY

A general comparison of the six alternative projects, describing the required facilities and stages of construction is summarized in Table 7-8. The capital costs, by stage, and first year annual cost are summarized in Table 7-9.

Engineering studies involved a review and evaluation of various alternatives of surface water supply development. Included were design factors, criteria, conditions prevailing with use of each source, and finally, the development of basic cost data.

TABLE 7-7  
USCE PALOUSE BASIN ALTERNATE  
PROJECT COST SUMMARY

|   |                   |                     |
|---|-------------------|---------------------|
| First Stage (1975) Capital Costs            |                   |                     |
| Transmission Line & Appurtenances           |                   | \$ 3,090,000        |
| Terminal Reservoirs                         |                   | 865,000             |
| Palouse Pumping Plant                       |                   | 886,800             |
| Laird Reservoir (M & I share)               |                   | 2,404,000           |
| Water Treatment Plant                       |                   | 1,675,000           |
| Palouse Intake & Diversion Dam              |                   | 510,000             |
|   | Subtotal          | <u>\$ 9,430,800</u> |
|   | 18% Contingencies | 1,697,500           |
|   | 12% Engineering   | 1,131,700           |
|   | TOTAL             | <u>\$12,260,000</u> |
| Second Stage (1990) Capital Costs           |                   |                     |
| Palouse Pumping Plant                       |                   | <u>\$ 231,100</u>   |
|   | Subtotal          | \$ 231,100          |
|   | 18% Contingencies | 41,600              |
|   | 12% Engineering   | 27,800              |
|   | TOTAL             | <u>\$ 300,500</u>   |
| Third State (2000) Capital Costs            |                   |                     |
| Palouse Pumping Plant                       |                   | \$ 520,000          |
| Water Treatment Plant                       |                   | 1,740,000           |
| Terminal Reservoir                          |                   | 100,000             |
|   | Subtotal          | <u>\$ 2,360,000</u> |
|   | 18% Contingencies | 425,100             |
|   | 12% Engineering   | 283,300             |
|   | TOTAL             | <u>\$ 3,068,400</u> |
| 1975 ANNUAL COSTS                           |                   |                     |
| Amortization of First Stage Capital Costs   |                   |                     |
| (30 years at 7% per annum)                  |                   | \$ 280,700          |
| (50 years at 3 1/8% per annum)              |                   | 363,400             |
| Operation and Maintenance of Physical Plant |                   | 233,290             |
| Power                                       |                   | 29,700              |
|   | TOTAL             | <u>\$ 907,090</u>   |




TABLE 7-8  
SUMMARY OF MAJOR FACILITIES

| <u>Facility and Construction Staging</u> | <u>Potlatch River</u> | <u>Clearwater River</u> | <u>USCE Palouse Basin</u> | <u>Snake River</u> | <u>Palouse River Basin</u> | <u>Troy Watershed</u> |
|--|-----------------------|-------------------------|---------------------------|--------------------|----------------------------|-----------------------|
| Dam & Reservoir                          |                       |                         |                           |                    |                            |                       |
| First Stage                              | 22,000 AF (1)         | None                    | 70,000 AF (1)             | None               | 15,000 AF (1)              | 22,700 AF (2)         |
| Second Stage                             |                       |                         |                           |                    |                            | 13,260 AF (2)         |
| Third Stage                              |                       |                         |                           |                    |                            | 4,250 AF (1)          |
| Pipelines                                |                       |                         |                           |                    |                            |                       |
| First Stage                              | 20 miles              | 31.5 miles              | 24 miles                  | 27.5 miles         | 31 miles                   | 33 miles              |
| Second Stage                             |                       |                         |                           | 19 miles           |                            | 9.5 miles             |
| Third Stage                              | 20 miles              | 31.5 miles              |                           |                    | 9.5 miles                  | 2 miles               |
| Treatment Plants                         |                       |                         |                           |                    |                            |                       |
| First Stage                              | 15 mgd                | 15 mgd                  | 15 mgd                    | 15 mgd             | 15 mgd                     | 18 mgd                |
| Second Stage*                            |                       |                         |                           |                    |                            |                       |
| Third Stage*                             | 5 mgd                 | 5 mgd                   | 5 mgd                     | 5 mgd              | 5 mgd                      | 2 mgd                 |
| Pumping Plants                           |                       |                         |                           |                    |                            |                       |
| First Stage                              | 2                     | 2                       | 2                         | 2                  | 2                          | 3                     |
| Second Stage*                            |                       |                         | 1                         | 2                  | 1                          | 3                     |
| Third Stage*                             | 2                     | 2                       | 1                         |                    |                            | 2                     |
| Terminal Storage                         |                       |                         |                           |                    |                            |                       |
| First Stage                              | 25 mg                 | 25 mg                   | 16 mg                     | 16 mg              | 10 mg                      | 16 mg                 |
| Second Stage                             | 11 mg                 | 11 mg                   |                           | 8 mg               |                            |                       |
| Third Stage                              | 11 mg                 | 11 mg                   | 4 mg                      |                    | 20 mg                      | 14 mg                 |


VII-27

\* Additions or Modifications



( ) Denote number of storage sites




A-1 PALOUSE BASIN PROJECT




A-2 PALOUSE BASIN PROJECT









B-1 U.S.C.E. PALOUSE BASIN PROJECT

STATIONING IN THOUSANDS OF FEET




B-2 U.S.C.E. PALOUSE BASIN PROJECT






# Snake River Transmission Line



STATIONING IN THOUSANDS OF FEET

Snake River Project D-1

# Snake River Transmission Line



Snake River Project D-2

TABLE 7-9  
SUMMARY OF CAPITAL COSTS (\$1,000)

| <u>Alternative Project</u> | <u>First Stage</u> | <u>Second Stage</u> | <u>Third Stage</u> | <u>First Year Annual Costs</u> |
|----------------------------|--------------------|---------------------|--------------------|--------------------------------|
| Snake River                | \$ 9,014           | \$ 4,772            | \$ 896             | \$ 1,143                       |
| Palouse River Basin        | \$14,600           | \$ 345              | \$ 4,062           | \$ 1,457                       |
| Troy Watershed             | \$14,544           | \$ 9,149            | \$ 5,572           | \$ 1,435                       |
| Potlatch River             | \$15,555           | \$ 683              | \$ 8,194           | \$ 1,516                       |
| Clearwater River           | \$14,498           | \$ 683              | \$ 9,506           | \$ 1,556                       |
| USCE-Palouse Basin         | \$12,260           | \$ 301              | \$ 3,068           | \$ 907                         |



In developing specific alternatives, two such schemes evolved as the better approaches of the six selections. Under the plan for the Snake River Project, the shortest conveyance distance would occur; the project could be made available sooner than any other scheme; and the lowest first stage capital cost would be required. The project does require, however, sizable construction requirements in the second stage.

The project indicating the lowest annual cost is through joint construction of a multi-purpose project on the North Fork of the Palouse River. Since much of the studies and design would be accomplished by the USCE, this project would in contrast, probably have the longest implementation and construction period, up to 10 or 15 years. Unless the communities to be served proceeded with an interim development plan, such as a seasonal use Palouse River intake or temporary dam structure, considerable expenditures will be required to expand the existing well system, until the project is available.

## ORGANIZATION AND FINANCING

### GENERAL

Equally important to the requirements of engineering design, planning and feasibility, are the organization and financing aspects of water supply. Organization should allow an early, orderly start of the project, benefit all future users, and be capable of efficiently operating as a regional function. Financing of the proposed surface water supply schemes must consider an equitable cost to all users, a rate schedule comparable to present rates or a minimum of initial increase, full advantage of available federal financing methods and the advantages of a central "wholesale" water supply agency.

### OPERATING STRUCTURE

Ideally, the implementing body responsible for the ultimate operation of the proposed water system should have the authority to appropriate and transfer surface water, construct, operate and finance the water project and contract for the sale of wholesale water to the communities. These capabilities as well as many others such as the authority to hold elections, set district boundaries, and bonding ability are essentially those powers available to a normal water district or municipality.

Obviously the creation of an operating structure is complicated by the political subdivision of the Pullman-Moscow area. To create this structure, the legal implications of the political subdivision would require extensive research and the probable enactment of special legislation in both states. Since by direction of the scope of the report, the legal aspects involved with the entire project were to be excluded, the recommendations contained herein concerning the creation of this implementation body are presented in theory only, assuming that the legal mechanics required to create such a structure will be given due consideration by future study.

Contact was made with representatives of the International Utilities Corporation to discuss the possibility of private ownership of the proposed water system as opposed to public ownership. The obvious advantage of such private ownership is that the aforementioned legal difficulties encountered by the creation of a public authority would be significantly reduced. Private ownership would have the advantage of being able to use its own capital and methods to construct, operate and finance the water project, yet the consumer would be protected by regulations imposed by public utility commissions. The obvious disadvantage of private ownership which prevents serious consideration of such action is the high project development cost involved. The water rates which would result from such action would undoubtedly be higher because the private corporation would not be eligible for federal grants, taxes would have to be incorporated into the rate of return, and additionally, the market value of private capital would greatly exceed that required through tax exempt bonds. Private "money" will simply cost more because of the demand for a higher yield.

Consideration was given to the possibility of one of the legal entities individually taking over the operating structure and in turn selling the water to other communities. Such procedures would permit the creation of an operating structure under existing law, thereby again eliminating the legal problems encountered with the multiple ownership concept which crosses political boundaries. Two factors prevent recommendation of this type of ownership of operating structure. First, such operation would result in unequal representation in the administrative authority thus creating a tremendous potential for dissatisfaction. Secondly, the high cost of any proposed projects would probably exceed the financing capabilities of the legal entity sponsoring the project.

The recommended type of operating structure envisions multiple ownership through an interstate wholesale water district. It is recognized that the creation of this type of structure would undoubtedly require the same empowering legislation to be passed in both states. However, this is the only readily apparent manner in which the operating structure can be empowered with the proper authority to implement and operate the water system. The basic concept of this type of ownership provides equal representation for all four legal entities

and maintains independent control in all matters concerning the operation of the water system. This type of operating structure could then contract for the sale of wholesale water to each of the four legal entities and use the revenue therein derived to operate and amortize the physical plant. This concept has the obvious advantage in that it does not require any division of the ownership in proportion to the consumption of any particular legal entity involved.

It is therefore recommended that legislation empowering the creation of this interstate wholesale water district be carefully drafted and submitted to the respective state legislature for approval. The basic authority granted by such legislation should be essentially the same provided for an intrastate water district and additionally make provision for the formation, operation and dissolution of the administrative body.

To maintain equal representation of all four legal entities, yet permit the operating structure to remain independent, it might be suggested that the operating structure be composed of seven individuals, one appointed member from each legal entity, one elected member from each community at large and a general manager of the water system with equal voting rights.

#### PROJECT FINANCING

Due to the initial high construction cost of all the alternates proposed, it was considered imperative to investigate all possible sources of federal funding. Representatives from the U. S. Army Corps of Engineers, the U. S. Bureau of Reclamation, the Soil Conservation Service, and the Department of Housing and Urban Development were consulted to determine the feasibility of either federal grants or loans from the respective agencies. Programs which provided feasible assistance were then incorporated into financial plans of the more favorable alternates.

#### U. S. ARMY CORPS OF ENGINEERS (USCE)

Discussions with representatives of the USCE revealed that M & I water projects can be financed under the Water Supply Act of 1958 as amended (Title III Public Law 85-500). The primary objective of this legislation is the development of multiple use projects, but the act does contain specific provisions for the inclusion of M & I water supply as one such possible use. Under certain conditions the act further provides federal financing for the construction of M & I storage and conveyance facilities at interest rates specifically outlined by the legislation. As there has been little precedent for such projects, especially the inclusion of conveyance facilities, the eligibility of any project would ultimately be based on the interpretation made by the Office of the Chief Engineer.

The actual interest rate involved for repayment under the Water Supply Act is currently 3.342 per cent, a factor which provides significant advantages to participation under this act. For M & I allocations principle and interest are based only on the amount of water used. Additionally, the interest can be deferred for the first 10 years after which time the annual interest on the entire M & I allocation must be paid. The entire loan must be repaid within a period of fifty years. Due to the advantages involved with this particular federal program, a detailed financial plan utilizing the USCE concept has been prepared and is presented in a later section.

#### U. S. BUREAU OF RECLAMATION (BOR)

The regional office of this agency, located in Boise, Idaho, was contacted in order to determine the possible financial assistance which may be available. The Bureau of Reclamation can also provide financial assistance for M & I water under the Water Supply Act of 1958 with the same provisions allowed the USCE. However, such application would have to involve Bureau sponsorship of a multiple use project, similar to the one previously presented the P-MWRC by officials of that agency.

Additionally, a fund program provided by the Small Reclamation Projects Act, (70-1044), Public Law 984, permits the Bureau of Reclamation to fund an M & I water supply provided that such a supply is an incidental use of a multiple purpose project whose primary purpose is irrigation. Public Law 984 also stipulates that the maximum project cost cannot exceed \$10,000,000. Since most of the alternates herein presented propose single-purpose storage facilities and exceed a cost of \$10,000,000, it is apparent that Public Law 984 cannot be of significant assistance.

#### DEPARTMENT OF HOUSING AND URBAN DEVELOPMENT (HUD)

This federal agency can provide either a direct grant or loan to municipal water supply and distribution projects. However, the regional office of HUD has established an administrative grant limitation of \$500,000 and a maximum loan limitation of \$1,000,000 per project. Due to present budget limitations, no funds are available for either large grants or loans. Since construction is not anticipated before the year 1975, it would be reasonable to expect some financial assistance from this agency if immediate application were made, thus permitting HUD to anticipate and budget the expenditure by the year 1975.

Although this agency indicated that little financial assistance could be provided in the immediate future, the HUD offices did display a keen interest and verbal approval of the proposed project. The concept of the four legal entities uniting to seek a common water supply has special appeal because it is somewhat unique and highly consistent with the objectives of this particular federal program.

Since federal funds from this agency cannot be confirmed at this time, it would not seem prudent to include them in the financial plans herein developed. It is strongly recommended that immediate application be made to this agency as this additional federal assistance would result in a reduction of the water rates herein proposed.

## SOIL CONSERVATION SERVICE (SCS)

Under Public Law 566, municipal and industrial water projects can receive loans from the Farmers Home Administration through the Soil Conservation Service, provided the watershed being developed contains less than 250,000 acres, or can be broken into increments of less than 250,000 acres, and the project for each watershed does not exceed a cost of \$5,000,000. A federal loan may be advanced for the portion of the future storage contained in the reservoirs. However, the cost allocated for future M & I storage cannot exceed thirty per cent of the total cost of the reservoir. No federal monies may be secured for the construction of transmission lines, pumping stations, water treatment plants or storage reservoirs, except in cases of joint use for irrigation.

These conditions indicate that eligible projects would include the Potlatch River Project, the Palouse River Project, and the Troy Watershed Development. It must be noted, however, that even if the maximum allotment, thirty per cent of the proposed cost of the reservoirs, were to be received, none of these projects could be completed at a cost less than that anticipated for the Snake River Plan.

## FINANCIAL PLAN - SNAKE RIVER

A conventional financial plan indicated that the wholesale water cost would range from 35.8 cents per thousand gallons to 16.6 per thousand gallons if only revenue bonds were employed and wholesale water costs adjusted annually to generate sufficient revenue. See Plan A, Table 8-1. This aspect of straight financing is a hardship during the first few years when not only the entire debt service payments will be made in addition to the O & M cost, but a revenue bond guarantee fund must be established resulting in an extremely high cost for the first five years. Due to the wide range in these costs, it would also not appear feasible to stabilize a water cost based on the 35 cents as initially encountered because the revenues would be far too excessive in the ensuing years.

TABLE 8-1  
SNAKE RIVER PROJECT - FINANCIAL PLAN A

| Year | Staged<br>Capital<br>Costs | First Bond Issue<br>Payment | Guarantee Fund       | Second Bond Issue<br>Payment | Guarantee Fund      | Third Bond Issue<br>Payment | Guarantee Fund      | O & M   | Power   | Total<br>Annual Cost | Q<br>Bg/Yr | Rate<br>¢/1000 gal. |
|------|----------------------------|-----------------------------|----------------------|------------------------------|---------------------|-----------------------------|---------------------|---------|---------|----------------------|------------|---------------------|
| 1975 | 9,014,000                  | 726,400 <sup>1</sup>        | 145,300 <sup>2</sup> |                              |                     |                             |                     | 250,000 | 167,000 | 1,228,700            | 3.6        | 35.8                |
| 1976 |                            | 726,400                     | 145,300              |                              |                     |                             |                     | 254,000 | 170,750 | 1,296,450            | 3.8        | 34.2                |
| 1977 |                            | 726,400                     | 145,300              |                              |                     |                             |                     | 258,000 | 174,500 | 1,304,200            | 3.99       | 32.7                |
| 1978 |                            | 726,400                     | 145,300              |                              |                     |                             |                     | 262,000 | 178,250 | 1,311,950            | 4.18       | 31.5                |
| 1979 |                            | 726,400                     | 145,300              |                              |                     |                             |                     | 266,000 | 182,000 | 1,319,700            | 4.35       | 30.3                |
| 1980 |                            | 726,400                     |                      |                              |                     |                             |                     | 270,000 | 185,750 | 1,182,150            | 4.5        | 26.3                |
| 1981 |                            | 726,400                     |                      |                              |                     |                             |                     | 274,000 | 189,500 | 1,189,900            | 4.62       | 25.7                |
| 1982 |                            | 726,400                     |                      |                              |                     |                             |                     | 278,000 | 193,250 | 1,197,650            | 4.74       | 25.3                |
| 1983 |                            | 726,400                     |                      |                              |                     |                             |                     | 282,000 | 197,000 | 1,205,400            | 4.85       | 24.8                |
| 1984 |                            | 726,400                     |                      |                              |                     |                             |                     | 286,000 | 200,750 | 1,213,150            | 4.96       | 24.4                |
| 1985 |                            | 726,400                     |                      |                              |                     |                             |                     | 290,000 | 204,500 | 1,220,900            | 5.06       | 24.1                |
| 1986 |                            | 726,400                     |                      |                              |                     |                             |                     | 294,000 | 208,250 | 1,228,650            | 5.16       | 23.8                |
| 1987 |                            | 726,400                     |                      |                              |                     |                             |                     | 298,000 | 212,000 | 1,236,400            | 5.26       | 23.4                |
| 1988 |                            | 726,400                     |                      |                              |                     |                             |                     | 302,000 | 215,750 | 1,244,150            | 5.36       | 23.2                |
| 1989 |                            | 726,400                     |                      |                              |                     |                             |                     | 306,000 | 219,500 | 1,251,900            | 5.46       | 22.9                |
| 1990 |                            | 726,400                     |                      |                              |                     |                             |                     | 310,000 | 223,250 | 1,259,650            | 5.56       | 22.6                |
| 1991 |                            | 726,400                     |                      |                              |                     |                             |                     | 314,000 | 227,000 | 1,267,400            | 5.62       | 22.5                |
| 1992 |                            | 726,400                     |                      |                              |                     |                             |                     | 318,000 | 230,750 | 1,275,150            | 5.68       | 22.4                |
| 1993 |                            | 726,400                     |                      |                              |                     |                             |                     | 322,000 | 234,500 | 1,282,900            | 5.74       | 22.3                |
| 1994 |                            | 726,400                     |                      |                              |                     |                             |                     | 326,000 | 238,250 | 1,290,650            | 5.80       | 22.2                |
| 1995 | 4,772,000 <sup>3</sup>     | 726,400                     |                      | 385,000                      | 77,000 <sup>2</sup> |                             |                     | 330,000 | 242,000 | 1,760,400            | 5.86       | 30.0                |
| 1996 |                            | 726,400                     |                      | 385,000                      | 77,000              |                             |                     | 334,000 | 245,750 | 1,768,150            | 5.92       | 29.8                |
| 1997 |                            | 726,400                     |                      | 385,000                      | 77,000              |                             |                     | 338,000 | 249,500 | 1,775,900            | 5.98       | 29.7                |
| 1998 |                            | 726,400                     |                      | 385,000                      | 77,000              |                             |                     | 342,000 | 253,250 | 1,783,650            | 6.04       | 29.6                |
| 1999 |                            | 726,400                     |                      | 385,000                      | 77,000              |                             |                     | 346,000 | 257,000 | 1,791,400            | 6.10       | 29.4                |
| 2000 | 896,000 <sup>4</sup>       | 726,400                     |                      | 385,000                      |                     | 72,300                      | 14,500 <sup>2</sup> | 350,000 | 260,760 | 1,808,950            | 6.16       | 29.3                |
| 2001 |                            | 726,400                     |                      | 385,000                      |                     | 72,300                      | 14,500              | 354,000 | 264,500 | 1,816,700            | 6.22       | 29.2                |
| 2002 |                            | 726,400                     |                      | 385,000                      |                     | 72,300                      | 14,500              | 358,000 | 268,250 | 1,824,450            | 6.28       | 29.1                |
| 2003 |                            | 726,400                     |                      | 385,000                      |                     | 72,300                      | 14,500              | 362,000 | 272,000 | 1,832,200            | 6.34       | 29.0                |
| 2004 |                            | 726,400                     |                      | 385,000                      |                     | 72,300                      | 14,500              | 366,000 | 275,750 | 1,839,950            | 6.40       | 28.8                |
| 2005 |                            |                             |                      | 385,000                      |                     | 72,300                      |                     | 370,000 | 279,500 | 1,106,800            | 6.46       | 17.2                |
| 2006 |                            |                             |                      | 385,000                      |                     | 72,300                      |                     | 374,000 | 283,250 | 1,114,550            | 6.52       | 17.1                |
| 2007 |                            |                             |                      | 385,000                      |                     | 72,300                      |                     | 378,000 | 287,000 | 1,122,300            | 6.58       | 17.1                |
| 2008 |                            |                             |                      | 385,000                      |                     | 72,300                      |                     | 382,000 | 290,750 | 1,130,050            | 6.64       | 17.0                |
| 2009 |                            |                             |                      | 385,000                      |                     | 72,300                      |                     | 386,000 | 295,500 | 1,137,800            | 6.70       | 17.0                |
| 2010 |                            |                             |                      | 385,000                      |                     | 72,300                      |                     | 390,000 | 298,250 | 1,145,550            | 6.76       | 16.9                |
| 2011 |                            |                             |                      | 385,000                      |                     | 72,300                      |                     | 394,000 | 302,000 | 1,153,300            | 6.82       | 16.9                |
| 2012 |                            |                             |                      | 385,000                      |                     | 72,300                      |                     | 398,000 | 305,750 | 1,161,050            | 6.88       | 16.9                |
| 2013 |                            |                             |                      | 385,000                      |                     | 72,300                      |                     | 402,000 | 309,500 | 1,168,800            | 6.94       | 16.8                |
| 2014 |                            |                             |                      | 385,000                      |                     | 72,300                      |                     | 406,000 | 313,250 | 1,176,550            | 7.00       | 16.8                |
| 2015 |                            |                             |                      | 385,000                      |                     | 72,300                      |                     | 414,000 | 320,750 | 1,184,300            | 7.06       | 16.8                |
| 2016 |                            |                             |                      | 385,000                      |                     | 72,300                      |                     | 418,000 | 324,500 | 1,192,050            | 7.12       | 16.7                |
| 2017 |                            |                             |                      | 385,000                      |                     | 72,300                      |                     | 422,000 | 328,250 | 1,199,800            | 7.18       | 16.7                |
| 2018 |                            |                             |                      | 385,000                      |                     | 72,300                      |                     | 426,000 | 332,000 | 1,207,550            | 7.24       | 16.7                |
| 2019 |                            |                             |                      | 385,000                      |                     | 72,300                      |                     | 430,000 | 335,750 | 1,215,300            | 7.30       | 16.6                |
| 2020 |                            |                             |                      | 385,000                      |                     | 72,300                      |                     |         |         | 1,223,050            | 7.36       | 16.6                |

1 Revenue bonds @ 7% for 30 years.

2 Equal to one annual payment in five years.

3 Second stage costs

4 Third stage costs



TABLE 8-2  
SNAKE RIVER PROJECT - FINANCIAL PLAN B

| Year | Bond No. 1<br>Payment | Staged<br>Capital<br>Costs | O & M   | Power   | Total Annual<br>Cost | Q<br>Bg/Yr | Rate<br>¢/1000 gal. | Total Revenue<br>Annual | Annual Net<br>Revenue | Annual Revenue<br>Invested | Value of<br>Investment | Cash on<br>Hand |
|------|-----------------------|----------------------------|---------|---------|----------------------|------------|---------------------|-------------------------|-----------------------|----------------------------|------------------------|-----------------|
| 1971 |                       |                            |         |         | 0                    | 2.93       | 20                  |                         |                       | 586,000                    | --                     |                 |
| 1972 |                       |                            |         |         | 0                    | 3.10       | 20                  |                         |                       | 610,000                    | --                     |                 |
| 1973 |                       |                            |         |         | 0                    | 3.27       | 20                  |                         |                       | 654,000                    | --                     |                 |
| 1974 |                       |                            |         |         | 0                    | 3.34       | 20                  |                         |                       | 668,000                    | --                     |                 |
| 1975 | 545,000 <sup>1</sup>  | 9,014,000                  | 250,000 | 167,000 | 962,000              | 3.6        | 25                  | 900,000                 | 657,000               | 900,000                    | 3,883,000 <sup>2</sup> | 657,000         |
| 1976 | 545,000               |                            | 254,000 | 170,750 | 969,750              | 3.8        | 25                  | 950,000                 | (19,750)              | 0                          | 0                      | 637,250         |
| 1977 | 545,000               |                            | 258,000 | 174,500 | 977,500              | 3.99       | 25                  | 1,000,000               | 22,500                | 0                          | 0                      | 659,750         |
| 1978 | 545,000               |                            | 262,000 | 178,250 | 985,250              | 4.18       | 25                  | 1,045,000               | 59,750                | 0                          | 0                      | 719,500         |
| 1979 | 545,000               |                            | 266,000 | 182,000 | 993,000              | 4.35       | 25                  | 1,090,000               | 97,000                | 0                          | 0                      | 816,500         |
| 1980 | 545,000               |                            | 270,000 | 185,750 | 1,000,750            | 4.50       | 25                  | 1,125,000               | 124,250               | 100,000                    | 107,000                | 840,750         |
| 1981 | 545,000               |                            | 274,000 | 189,500 | 1,008,500            | 4.62       | 25                  | 1,155,000               | 146,500               | 100,000                    | --                     | 887,250         |
| 1982 | 545,000               |                            | 278,000 | 193,250 | 1,016,250            | 4.74       | 25                  | 1,185,000               | 168,750               | 100,000                    | --                     | 956,000         |
| 1983 | 545,000               |                            | 282,000 | 197,000 | 1,024,000            | 4.85       | 25                  | 1,212,500               | 188,500               | 100,000                    | --                     | 1,044,500       |
| 1984 | 545,000               |                            | 286,000 | 200,750 | 1,031,750            | 4.96       | 25                  | 1,240,000               | 208,250               | 100,000                    | --                     | 1,152,750       |
| 1985 | 545,000               |                            | 290,000 | 204,500 | 1,039,500            | 5.06       | 25                  | 1,265,000               | 225,500               | 200,000                    | --                     | 1,178,250       |
| 1986 | 545,000               |                            | 294,000 | 208,250 | 1,047,250            | 5.16       | 25                  | 1,290,000               | 242,750               | 200,000                    | --                     | 1,221,000       |
| 1987 | 545,000               |                            | 298,000 | 212,000 | 1,055,000            | 5.26       | 25                  | 1,315,000               | 260,000               | 200,000                    | --                     | 1,281,000       |
| 1988 | 545,000               |                            | 302,000 | 215,750 | 1,062,750            | 5.36       | 25                  | 1,340,000               | 277,250               | 200,000                    | --                     | 1,358,250       |
| 1989 | 545,000               |                            | 306,000 | 219,500 | 1,070,500            | 5.46       | 25                  | 1,365,000               | 294,500               | 200,000                    | --                     | 1,452,750       |
| 1990 | 545,000               |                            | 310,000 | 223,250 | 1,078,250            | 5.56       | 25                  | 1,390,000               | 311,750               | 300,000                    | --                     | 1,464,500       |
| 1991 | 545,000               |                            | 314,000 | 227,000 | 1,086,000            | 5.62       | 25                  | 1,405,000               | 319,000               | 300,000                    | --                     | 1,483,500       |
| 1992 | 545,000               |                            | 318,000 | 230,750 | 1,093,750            | 5.68       | 25                  | 1,420,000               | 326,250               | 300,000                    | --                     | 1,509,750       |
| 1993 | 545,000               |                            | 322,000 | 234,500 | 1,101,500            | 5.74       | 25                  | 1,435,000               | 333,500               | 300,000                    | --                     | 1,543,250       |
| 1994 | 545,000               |                            | 326,000 | 238,250 | 1,109,250            | 5.80       | 25                  | 1,450,000               | 340,750               | 300,000                    | 4,470,000 <sup>3</sup> | 1,584,000       |
| 1995 | 545,000               | 4,772,000 <sup>3</sup>     | 330,000 | 242,000 | 1,117,000            | 5.86       | 25                  | 1,456,000               | 348,000 <sup>3</sup>  | 0                          | 0                      | 1,630,000       |
| 1996 | 545,000               |                            | 334,000 | 245,750 | 1,124,750            | 5.92       | 25                  | 1,480,000               | 355,250               | 300,000                    | 321,000                | 1,685,250       |
| 1997 | 545,000               |                            | 338,000 | 249,500 | 1,132,500            | 5.98       | 25                  | 1,495,000               | 362,500               | 300,000                    | --                     | 1,747,750       |
| 1998 | 545,000               |                            | 342,000 | 253,250 | 1,140,250            | 6.04       | 25                  | 1,510,000               | 369,750               | 300,000                    | --                     | 1,817,500       |
| 1999 | 545,000               |                            | 346,000 | 257,000 | 1,148,000            | 6.10       | 25                  | 1,525,000               | 377,000               | 300,000                    | 1,332,000 <sup>4</sup> | 1,894,500       |
| 2000 | 545,000               | 896,000 <sup>4</sup>       | 350,000 | 260,760 | 1,155,750            | 6.16       | 25                  | 1,540,000               | 384,250               | 300,000                    | 788,000                | 1,978,750       |
| 2001 | 545,000               |                            | 354,000 | 264,500 | 1,163,500            | 6.22       | 25                  | 1,555,000               | 391,500               | 300,000                    |                        | 2,070,250       |
| 2002 | 545,000               |                            | 358,000 | 268,250 | 1,171,250            | 6.28       | 25                  | 1,570,000               | 398,750               | 300,000                    |                        | 2,169,000       |
| 2003 | 545,000               |                            | 362,000 | 272,000 | 1,179,000            | 6.34       | 25                  | 1,585,000               | 406,000               | 300,000                    |                        | 2,275,000       |
| 2004 | 545,000               |                            | 366,000 | 275,750 | 1,186,750            | 6.40       | 25                  | 1,600,000               | 413,250               | 300,000                    |                        | 2,388,250       |
| 2005 |                       |                            | 370,000 | 279,500 | 649,500              | 6.46       | 20                  | 1,292,000               | 642,500               | 300,000                    |                        | 2,730,750       |
| 2006 |                       |                            | 374,000 | 283,250 | 657,250              | 6.52       |                     | 1,304,000               | 646,750               | 500,000                    |                        | 2,877,500       |
| 2007 |                       |                            | 378,000 | 287,000 | 665,000              | 6.58       |                     | 1,316,000               | 651,000               | 500,000                    |                        | 3,028,500       |
| 2008 |                       |                            | 382,000 | 290,750 | 672,750              | 6.64       |                     | 1,328,000               | 655,250               | 500,000                    |                        | 3,183,750       |
| 2009 |                       |                            | 386,000 | 295,500 | 680,500              | 6.70       |                     | 1,340,000               | 659,500               | 500,000                    |                        | 3,343,250       |
| 2010 |                       |                            | 390,000 | 298,250 | 688,250              | 6.76       |                     | 1,352,000               | 663,750               | 500,000                    |                        | 3,507,000       |
| 2011 |                       |                            | 394,000 | 302,000 | 696,000              | 6.82       |                     | 1,364,000               | 668,000               | 500,000                    |                        | 3,675,000       |
| 2012 |                       |                            | 398,000 | 305,750 | 703,750              | 6.88       |                     | 1,376,000               | 672,250               | 500,000                    |                        | 3,847,250       |
| 2013 |                       |                            | 402,000 | 309,500 | 711,500              | 6.94       |                     | 1,388,000               | 676,500               | 500,000                    |                        | 4,023,750       |
| 2014 |                       |                            | 406,000 | 313,250 | 719,250              | 7.00       |                     | 1,400,000               | 680,750               | 500,000                    |                        | 4,204,500       |
| 2015 |                       |                            | 410,000 | 317,000 | 727,000              | 7.06       |                     | 1,412,000               | 685,000               | 500,000                    |                        | 4,389,500       |
| 2016 |                       |                            | 414,000 | 320,750 | 734,750              | 7.12       |                     | 1,424,000               | 689,250               | 500,000                    |                        | 4,578,750       |
| 2017 |                       |                            | 418,000 | 324,500 | 742,500              | 7.18       |                     | 1,436,000               | 693,500               | 500,000                    |                        | 4,772,250       |
| 2018 |                       |                            | 422,000 | 328,250 | 750,250              | 7.24       |                     | 1,448,000               | 697,750               | 500,000                    |                        | 4,970,000       |
| 2019 |                       |                            | 426,000 | 332,000 | 758,000              | 7.30       |                     | 1,460,000               | 702,000               | 500,000                    |                        | 5,172,000       |
| 2020 |                       |                            | 430,000 | 335,750 | 765,750              | 7.36       |                     | 1,472,000               | 706,250               | 500,000                    |                        | 5,378,250       |

1 6 3/4 million @ 7% for 30 years

2 Use entire amount for construction in 1975

3 Second stage costs

4 Third stage costs

An alternative financial plan, Plan B, Table 8-2, developed for the Snake River alternate, presents a better picture. Basically, it initiates an immediate charge of 20 cents per thousand gallons for all water used by the four agencies, which by the year 1975 would raise a revenue of \$3,883,000. If a portion of this investment is used to lower the initial capital cost to \$6,750,000, the annual amortization of the first bond issue is greatly reduced, consequently reducing the cost of the water for the first year. A cash reserve fund would also continue to be available. The net result of this plan is that in the first year of actual use, the water costs only need be raised to 25 cents per thousand gallons. It should be noted that during the first year, the proposed plan requires a deficit operation; however, this does not deplete the total cash on hand to an amount less than the annual payment required, a factor which will not prevent a proper bond sale. The possible effect of grants has not been shown which would in effect improve the cost requirements.

Beyond the first year, revenues steadily increase so that by 1980, investments may be placed in a sinking fund. Investments are gradually increased until by the time the second stage construction is required in 1995, \$4,470,000 would be accrued and could be applied against the anticipated second stage construction cost of \$4,472,000. Some additional expenditures would be required, however, by that date, and it is anticipated the cash balance of \$1,630,000 can be so applied. A \$300,000 annual investment can be continued beyond 1995 and will accrue funds sufficient for the third stage of construction in the year 2000. Beyond the year 2000, the revenues increase at an accelerating rate indicating that a rate reduction could be feasible. Consequently, a rate reduction to 20 cents per thousand gallons is shown in the year 2005. At this time, the annual sinking fund is also increased to \$500,000 and the revenue continues to increase as well as the cash balance on hand. By the year 2020, the value of this investment has grown to \$20,296,000 with a cash balance of \$5,378,000. Projections are extremely difficult to anticipate at this time beyond the year 2000; however, from the above information and the financial plan, it appears that possibly the 20 cents could be further reduced to 15 cents and still permit a positive cash balance to be shown at the year 2020.

Consideration was given to a third alternate financial plan for the Snake River. This plan suggest the sale of general obligation bonds prior to the year 1975 in the amount of \$3,883,000. These funds would be used in the same manner as the revenue funds which were created prior to the year 1975 in Plan B. Consideration was given to this concept in the event the public would accept a tax increase more readily than the immediate rate increase required in Plan B. Subsequent investigations concerning permissible debt limitations and interest limitations indicated that the sale of such bonds would be doubtful. The mechanics of combining a common bond issue, passing the separate referendums, and securing the necessary legislative action are extremely complex considering that the state law for both Washington and Idaho must be mutually satisfied. It also appears doubtful that sufficient money could be raised through a general obligation bond issue to appreciably reduce the initial capital cost. As an example of the limitations on such funds, it could be emphasized that the State of Idaho has a total debt limitation of \$2,000,000 with the current indebtedness being \$1,965,000. The community of Moscow has an indebtedness limitation of \$845,000 and an indebtedness of \$125,000, and the City of Pullman at the end of 1969 had an indebtedness of \$1,001,000 in general obligation bonds. In view of these facts, it becomes readily apparent that general obligation bonds could not be used to lower the initial cost of the project without revision of Idaho law or significant reduction of current indebtedness.

#### FINANCIAL PLAN - USCE PALOUSE BASIN PROJECT

Due to the advantages involved with the federal financing available under the Water Supply Act of 1958, an additional financial plan, Plan C, Table 8-3, is presented for the general concept developed by the USCE on the Palouse River. It must be noted, however, that this particular project cannot merit serious consideration without revision of Idaho Law. The 40th session of the Idaho legislature passed a bill which would permit reciprocal water transfer between the States of Idaho and Washington, however reciprocity is limited to municipal and industrial use only in the community of Pullman, Washington. Obviously, such a restriction eliminates downstream irrigation use in the State of Washington and negates the multiple use concept proposed in the USCE project. Therefore, the presentation of Plan C is predicated upon the assumption that this particular legislation can be revised to allow a multiple use project on the Palouse River.

TABLE 8-3  
USCE - PALOUSE BASIN PROJECT - FINANCIAL PLAN C

| Year | Staged<br>Capital<br>Costs | Federal Loan<br>50 yr. @3.342% <sup>1</sup> | Revenue Bond<br>30 yr. @7.0% <sup>2</sup> | O & M   | Power   | Total<br>Annual<br>Cost | Q<br>Bg/Yr | Rate<br>¢/1000 gal. | Total<br>Annual<br>Revenue | Net<br>Annual<br>Revenue | Cash on <sup>6</sup><br>Hand |
|------|----------------------------|---|---|---------|---------|-------------------------|------------|---------------------|----------------------------|--------------------------|------------------------------|
| 1973 |                            |   |   |         |         |                         | 3.27       | 10 <sup>5</sup>     | 327,000                    | 327,000                  | 327,000                      |
| 1974 |                            |   |   |         |         |                         | 3.34       | 10                  | 334,000                    | 334,000                  | 661,000                      |
| 1975 | 12,046,000                 | 363,400                                     | 280,700                                   | 233,290 | 29,700  | 907,090                 | 3.6        | 20                  | 720,000                    | (187,090) <sup>7</sup>   | 473,910                      |
| 1976 |                            | 363,400                                     | 280,700                                   | 237,010 | 31,650  | 912,760                 | 3.8        | 20                  | 760,000                    | (152,760)                | 321,150                      |
| 1977 |                            | 363,400                                     | 280,700                                   | 240,730 | 33,600  | 918,430                 | 3.99       | 20                  | 798,000                    | (120,430)                | 200,720                      |
| 1978 |                            | 363,400                                     | 280,700                                   | 244,450 | 35,550  | 924,100                 | 4.18       | 20                  | 836,000                    | (88,100)                 | 112,620                      |
| 1979 |                            | 363,400                                     | 280,700                                   | 248,170 | 37,500  | 929,770                 | 4.35       | 20                  | 870,000                    | (59,770)                 | 52,850                       |
| 1980 |                            | 363,400                                     | 280,700                                   | 251,890 | 39,450  | 935,440                 | 4.50       | 20                  | 900,000                    | (35,440)                 | 17,410                       |
| 1981 |                            | 363,400                                     | 280,700                                   | 255,610 | 41,400  | 941,110                 | 4.62       | 20                  | 924,000                    | (17,110)                 | 300                          |
| 1982 |                            | 363,400                                     | 280,700                                   | 259,330 | 43,350  | 946,780                 | 4.74       | 20                  | 948,000                    | 1,220                    | 1,520                        |
| 1983 |                            | 363,400                                     | 280,700                                   | 263,050 | 45,300  | 952,450                 | 4.85       | 20                  | 970,000                    | 17,550                   | 19,070                       |
| 1984 |                            | 363,400                                     | 280,700                                   | 266,770 | 47,250  | 958,120                 | 4.96       | 20                  | 992,000                    | 33,880                   | 52,950                       |
| 1985 |                            | 363,400                                     | 280,700                                   | 270,490 | 49,200  | 963,790                 | 5.06       | 20                  | 1,012,000                  | 48,210                   | 101,160                      |
| 1986 |                            | 363,400                                     | 280,700                                   | 274,210 | 51,150  | 969,460                 | 5.16       | 20                  | 1,032,000                  | 62,540                   | 163,700                      |
| 1987 |                            | 363,400                                     | 280,700                                   | 277,930 | 53,100  | 975,130                 | 5.26       | 20                  | 1,052,000                  | 76,870                   | 240,570                      |
| 1988 |                            | 363,400                                     | 280,700                                   | 281,650 | 55,050  | 980,800                 | 5.36       | 20                  | 1,072,000                  | 91,200                   | 331,770                      |
| 1989 |                            | 363,400                                     | 280,700                                   | 285,370 | 57,000  | 986,470                 | 5.46       | 20                  | 1,092,000                  | 105,530                  | 437,300                      |
| 1990 | 300,500 <sup>3</sup>       | 363,400                                     | 280,700                                   | 289,090 | 58,950  | 992,140                 | 5.56       | 20                  | 1,112,000                  | 119,860                  | 256,660                      |
| 1991 |                            | 363,400                                     | 280,700                                   | 292,810 | 60,900  | 997,810                 | 5.66       | 20                  | 1,132,000                  | 134,190                  | 390,850                      |
| 1992 |                            | 363,400                                     | 280,700                                   | 296,530 | 62,850  | 1,003,480               | 5.68       | 20                  | 1,136,000                  | 132,520                  | 523,370                      |
| 1993 |                            | 363,400                                     | 280,700                                   | 300,250 | 64,800  | 1,009,150               | 5.74       | 20                  | 1,148,000                  | 138,850                  | 662,220                      |
| 1994 |                            | 363,400                                     | 280,700                                   | 303,970 | 66,750  | 1,014,820               | 5.80       | 20                  | 1,160,000                  | 145,180                  | 807,400                      |
| 1995 |                            | 363,400                                     | 280,700                                   | 307,690 | 68,700  | 1,020,490               | 5.86       | 20                  | 1,172,000                  | 151,510                  | 958,910                      |
| 1996 |                            | 363,400                                     | 280,700                                   | 311,410 | 70,650  | 1,026,160               | 5.92       | 20                  | 1,184,000                  | 157,840                  | 1,116,750                    |
| 1997 |                            | 363,400                                     | 280,700                                   | 315,130 | 72,600  | 1,031,830               | 5.98       | 20                  | 1,196,000                  | 164,170                  | 1,280,920                    |
| 1998 |                            | 363,400                                     | 280,700                                   | 318,850 | 74,550  | 1,037,500               | 6.04       | 20                  | 1,208,000                  | 170,500                  | 1,451,420                    |
| 1999 |                            | 363,400                                     | 280,700                                   | 322,570 | 76,500  | 1,043,170               | 6.10       | 20                  | 1,220,000                  | 176,830                  | 1,628,250                    |
| 2000 | 3,068,400 <sup>4</sup>     | 363,400                                     | 409,400                                   | 326,290 | 78,450  | 1,177,540               | 6.16       | 20                  | 1,232,000                  | 54,460                   | 114,310                      |
| 2001 |                            | 363,400                                     | 409,400                                   | 330,010 | 80,400  | 1,183,210               | 6.22       | 20                  | 1,244,000                  | 60,790                   | 175,100                      |
| 2002 |                            | 363,400                                     | 409,400                                   | 333,730 | 82,350  | 1,188,880               | 6.28       | 20                  | 1,256,000                  | 67,120                   | 242,220                      |
| 2003 |                            | 363,400                                     | 409,400                                   | 337,450 | 84,300  | 1,194,550               | 6.34       | 20                  | 1,268,000                  | 73,450                   | 315,670                      |
| 2004 |                            | 363,400                                     | 409,400                                   | 341,170 | 86,250  | 1,200,220               | 6.40       | 20                  | 1,280,000                  | 79,780                   | 395,450                      |
| 2005 |                            | 363,400                                     | 128,700                                   | 344,890 | 88,200  | 925,190                 | 6.46       | 15                  | 969,000                    | 43,810                   | 439,260                      |
| 2006 |                            | 363,400                                     | 128,700                                   | 348,610 | 90,150  | 930,860                 | 6.52       | 15                  | 978,000                    | 47,140                   | 486,400                      |
| 2007 |                            | 363,400                                     | 128,700                                   | 352,330 | 92,100  | 936,530                 | 6.58       | 15                  | 987,000                    | 50,470                   | 536,870                      |
| 2008 |                            | 363,400                                     | 128,700                                   | 356,050 | 94,050  | 942,200                 | 6.64       | 15                  | 996,000                    | 53,800                   | 590,670                      |
| 2009 |                            | 363,400                                     | 128,700                                   | 359,770 | 96,000  | 947,870                 | 6.70       | 15                  | 1,005,000                  | 57,130                   | 647,800                      |
| 2010 |                            | 363,400                                     | 128,700                                   | 363,490 | 97,950  | 953,540                 | 6.76       | 15                  | 1,014,000                  | 60,460                   | 708,260                      |
| 2011 |                            | 363,400                                     | 128,700                                   | 367,210 | 99,900  | 959,210                 | 6.82       | 15                  | 1,023,000                  | 63,790                   | 772,050                      |
| 2012 |                            | 363,400                                     | 128,700                                   | 370,930 | 101,850 | 964,880                 | 6.88       | 15                  | 1,032,000                  | 67,120                   | 839,170                      |
| 2013 |                            | 363,400                                     | 128,700                                   | 374,650 | 103,800 | 970,550                 | 6.94       | 15                  | 1,041,000                  | 70,450                   | 909,620                      |
| 2014 |                            | 363,400                                     | 128,700                                   | 378,370 | 105,750 | 976,220                 | 7.00       | 15                  | 1,050,000                  | 73,780                   | 983,400                      |
| 2015 |                            | 363,400                                     | 128,700                                   | 382,090 | 107,700 | 981,890                 | 7.06       | 15                  | 1,059,000                  | 77,110                   | 1,060,510                    |
| 2016 |                            | 363,400                                     | 128,700                                   | 385,810 | 109,650 | 987,560                 | 7.12       | 15                  | 1,068,000                  | 80,440                   | 1,140,950                    |
| 2017 |                            | 363,400                                     | 128,700                                   | 389,530 | 111,600 | 993,230                 | 7.18       | 15                  | 1,077,000                  | 83,770                   | 1,224,720                    |
| 2018 |                            | 363,400                                     | 128,700                                   | 393,250 | 113,550 | 998,900                 | 7.24       | 15                  | 1,086,000                  | 87,100                   | 1,311,820                    |
| 2019 |                            | 363,400                                     | 128,700                                   | 396,970 | 115,500 | 1,004,570               | 7.30       | 15                  | 1,095,000                  | 90,430                   | 1,402,250                    |
| 2020 |                            | 363,400                                     | 128,700                                   | 400,490 | 117,600 | 1,010,190               | 7.36       | 15                  | 1,104,000                  | 93,810                   | 1,496,060                    |

1 Eligible project cost for USCE financing = \$8,776,000.

2 Project cost financed by local funding = \$3,270,000 (First Stage), \$1,500,000 (Third Stage).

3 Second stage capital costs from cash on hand = \$300,500.

4 Third stage capital costs from cash on hand = \$1,568,400.

5 Rate instituted prior to project use to accumulate cash reserve.

6 Investment at short term interest rates not shown.

7 ( ) indicate deficit year.

The financial plan presented for the Palouse River proposes an initial water cost of ten cents per thousand gallons be levied before 1973, two years prior to project use. Assuming construction will be complete in 1975, the revenue will raise \$661,000. A portion of this fund could be invested to create a sinking fund for future construction purposes, and the remainder of the fund used to offset the deficit operation expected during the early years of operation. It should be noted that construction grants could possibly reduce or eliminate a deficit operation by lowering first stage bonding requirements. Another possible plan could utilize a deferred principle plan, but might require higher interest rates. By the year 1982 sufficient revenue is projected to pay the annual costs and accrue a sinking fund from the surplus revenue for second and third stage capital costs as shown.

Physical plant expenditures for the USCE Palouse Project are proposed in four different forms. The first two are the annual amortization costs incurred from the initial physical plan construction. The annual payment on the portion of the plant which is eligible for federal financing under the Water Supply Act amounts to \$363,500 per year, and \$280,700 per year is required to meet payments for that portion of the first stage physical plant not eligible for federal financing under the Act (water treatment plant and terminal storage). In the year 1990, second stage construction on the pumping plants will require an additional expenditure of \$300,500. However, the invested cash on hand at that date has sufficient value to meet this expenditure; consequently, the financial plan projects a cash payment of this particular construction phase. In the year 2000, additional construction is required and will cost an estimated \$3,068,400. Again, the value of the sinking fund is sufficient to partly cover this expenditure and the financial plan accordingly projects a \$1,500,000 revenue bond to raise the additional funds. Beyond the year 2000, additional investments are projected to offset the anticipated construction expenses beyond the year 2020. However, it should be noted that a rate decrease to 15 cents per thousand gallons can be effected in the year 2005 and still permit a reasonable rate of return.

## USCE FINANCING - SNAKE RIVER

An obvious alternative method of financing the proposed Snake River Project is the application of federal funding through the Water Supply Act of 1958, similar to that previously presented for the USCE Palouse River Plan. Through the application of the low interest rate provided by the Water Supply Act to the conveyance facilities required for the development of the Snake River supply, considerably lower amortizing costs are realized. Such application results in water costs very similar to those experienced by the Palouse River Plan during the year 1975. For example, in the year 1975, the total annual cost for the Palouse River Plan was presented at \$907,190, and similar financing would result in a total annual cost in the year 1975 for the Snake River of \$923,200. It is obvious from comparison of these two figures that the water rate of 20 cents per thousand gallons would be additionally sufficient to finance the development of the Snake River alternate under similar conditions.

Two factors prevent serious consideration of this concept. The first being that the second stage costs involved with the Snake River Plan greatly exceed those anticipated for the USCE Palouse River Plan, and these higher future costs would require either an increase in the rate of 20 cents per thousand gallons or continuation of such rate far beyond the year 2005. More importantly, application of the Water Supply Act of 1958 to financing of the Snake River Plan would be much more difficult to secure. Guidelines used by the USCE for application of the Water Supply Act indicate that... "criteria for considering whether or not water supply is authorized in a completed project by the Water Supply Act of 1958 should be somewhat more restrictive than in the case of adding water supply as a purpose prior to construction." Since Lower Granite Pool essentially constitutes a "completed project," it seems reasonable to assume that application of the Water Supply Act would definitely show preference to the USCE Palouse River Plan rather than the Snake River Project under similar conditions. This preference compounded with the lack of clear definition and precedent for the funding of the conveyance facilities for either project, concludes that the USCE Palouse River Project has definite advantages over the Snake River Project for development under the Water Supply Act of 1958.

FINDINGS  
AND  
RECOMMENDATIONS

Implementation of a plan for developing a surface water supply should take place immediately. Demands for domestic water will outstrip the capabilities of the present system by 1975. Additional development of a ground water supply is recognized as being severely limited and future use should be only on a seasonal basis to supplement periods of peak use.

From the studies of potential surface water supply and development needs it is concluded that:

1. Water for the communities of Pullman and Moscow and the related universities will be in short supply within the next decade. Population trends indicate a definite need for area-wide water resource development.
2. Growth in urban communities will continue to be oriented towards the universities. The combined enrollment is estimated at 32,500 in 1980 and nearly 47,000 in 2020. By extension of projections to the entire Pullman-Moscow area, the served population is estimated at 68,500 in 1980 and 100,600 in 2020.
3. Virtually all surface water sources will require treatment and pumping for delivery to the communities. Assurance as to continual watershed protection is impossible and economics dictate use of withdrawal points subject to uncontrolled upstream use.
4. Water requirements for the Pullman-Moscow Area depend on daily and seasonal variables, consumptive trends and types of use. Peak demands of three times the average daily demand can be expected. The rate of consumptive use, while varying by type of user, can be expected to increase during the design period to about 200 gallons per day in 2020. Sprinkling has a significant effect on the demands, particularly during the months of June through September.

5. The greatest benefit would be realized for participation in multi-purpose projects where irrigation, flood protection, prevention of soil erosion, fish propagation, waterfowl habitats and possibly power generation can be incorporated. Sites on the North Fork of the Palouse River and Snake River provide the widest range of such benefits.
6. The plan for surface water supply development can be effectively carried out only on a regional basis.
7. To insure an adequate supply through a fifty year design period, a source capable of producing 7.4 billion gallons per year is required. First stage facilities should be provided with an average daily capacity of 15 mgd, expandable to 20 mgd by 2020.
8. The proposed water system should be operated by an agency having the authority to appropriate and transfer surface water, construct, operate and finance the project and contract for the sale of wholesale water to the communities. It should also have the capabilities to hold elections, set district boundaries and possess bonding ability.
9. Financing of the proposed water system must consider an equitable cost to all users, a rate schedule comparable to present rates or a minimum of initial increase, full advantage of available federal financing methods and the advantages of a central wholesale water supply agency.
10. Economic evaluation indicates two of the six projects reviewed in detail as the most feasible. The Snake River Project has the lowest first stage cost and the USCE Palouse Basin, a joint sponsored project, has the lowest annual costs.

In order to consolidate all recommendations pertaining to the planning, analysis, preliminary design, construction and financing of the water supply facilities, major points are summarized below. It was considered desirable to separate recommendations which imply general implementation from those which are specific to a particular alternate selection and allow final decisions by the Committee. In brief, it is recommended that:



1. The Pullman-Moscow Water Resources Committee review the report and make certain recommendations to the represented bodies as to its adoption and implementation.
2. A decision be made as to selection of the specific long range plan of water supply to be pursued.
3. Action be taken to secure appropriate state legislation which will establish and empower an interstate water district with the authority to appropriate water, sell revenue bonds, have equitable representation, construct and operate water treatment and conveyance facilities, and sell wholesale water in both Washington and Idaho.
4. A revenue system or appropriation program be implemented which will be sufficient to meet the financial requirements of the plan selected.
5. The adopted plan along with an application for construction grant and loan assistance be submitted as soon as possible to the Department of Housing and Urban Development.
6. The ground water and aquifers in the Pullman-Moscow Basin and areas south and east of Moscow continue to be investigated so to assure adequacy of conjunctive use with the surface water supply plan throughout the study period and beyond.
7. A detailed program and work schedule for implementation, financing, planning, manpower requirements, design and construction of the proposed facilities be developed immediately.

In the event the Snake River Project is selected, it is recommended that:

1. The Corps of Engineers be requested to review and study possible application of the Water Supply Act of 1958, as amended, to the proposed Snake River Project.
2. Immediate application be made to the Corps of Engineers for a withdrawal permit from the lower Granite Pool and Snake River for an initial amount of 22, 500 acre-feet.

3. The undertaking of preliminary engineering studies to include route surveying, soils investigations and facilities design be authorized as soon as possible in recognition of the time requirements for the proposed facilities.

In the event the Palouse Basin Project is selected, it is recommended that:

1. The report be immediately submitted to the Corps of Engineers with the request for a decision on participation in development of the proposed plan under the Water Supply Act of 1958, as amended, and a time schedule for engineering and construction.
2. Revisions be requested for the present Idaho Legislation (HB 509) on reciprocal exchange of water with the State of Washington limiting use of water to M & I only so to allow a multi-purpose project to be constructed to the benefit of both states.
3. A continuous water quality monitoring program be established on the Palouse River to obtain seasonal flow correlated data.
4. The appropriate water rights and agreements be secured in line with the proposed program of storage and stream flow regulation.

## REFERENCES

- (1) Buscemi, P. A., "Chemical and Detrital Features of Palouse River Idaho Runoff Flowage", Oikos, Vol. 20, January 1969.
- (2) Clarl, Coleman and Rupeks, Inc., Consulting Engineers, "Comprehensive Development Plan of Moscow, Idaho, 1965.
- (3) Eyer, J. M., "Pumping Plant Operation and Maintenance Costs", Journal of Irrigation and Drainage Division, ASCE, December 1965.
- (4) Federal Water Pollution Control Administration, "Water Quality Criteria", April 1968.
- (5) Idaho Code, Section 42-211 (HB 509) "Appropriation of Water for Use Outside the State" as amended 1970.
- (6) Idaho Department of Health, Engineering and Sanitation Division, Idaho Drinking Standards, adopted 1964.
- (7) Linaweaver, F. P., Geyer, J. C., Wolff, J. B., "Summary Report on the Residential Water Use Research Project", Journal of A. W. W. A., March 1967.
- (8) McKee and Wolf, "Water Quality Criteria", State Water Quality Control Board, Sacramento, California, 1963.
- (9) Pullman-Moscow Water Resources Committee, "Status Report", February 1969.
- (10) Pullman-Moscow Water Resources Committee, "Summary Report of Population Projections and Water Demand", October 1969.
- (11) Pullman-Moscow Water Resources Committee, Population Projections, November 1969.

- (12) Schmid, C.F. and Schmid, S.E., "Growth of Cities and Towns-State of Washington, Washington State Planning and Community Affairs Agency, 1969.
- (13) Stevens and Thompson, Inc., Consulting Engineers, "Master Plan for Water Distribution System, Moscow, Idaho", December 1962.
- (14) Stevens and Thompson, Inc., Consulting Engineers, "Water Works Improvements for Washington State University", February 1962.
- (15) Stevens, Thompson, Runyan & Ries, Inc., "Water System Study for Pullman, Washington", September 1966.
- (16) Sutherland, R.A., "Study of Future Water Supply of Pullman and Moscow, Including both Universities", August 1967.
- (17) Troy Watershed Development Committee Report and Data on RC&D Project, 1969.
- (18) U. S. Bureau of Reclamation, "Estimating Data - Pumping Plants", Series 150, Chapter 3, November 1958.
- (19) U. S. Bureau of Reclamation, "Lower Snake River Basin Project, Municipal and Industrial Water Supply, Pullman and Moscow Area", January 1968.
- (20) U. S. Corps of Engineers, "Palouse Basin Study", May 1968.
- (21) U. S. Corps of Engineers, "Palouse River Basin Economic Base Study", 1968.
- (22) U. S. Corps of Engineers, "Palouse River Basin Study, Municipal Water Supply Alternatives for Pullman-Moscow Area", January 1969.
- (23) U. S. Corps of Engineers, "Palouse River Basin Study, Status Report", September 1969.

- (24) U. S. Corps of Engineers, "Scoping Study for Palouse Basin," January 1970.
- (25) University of Illinois, "Influence of Raw Water Characteristics on Treatment", Proceedings, 11th Sanitary Engineering Conference, February 1969.
- (26) Washington State Highway Department, "Population Projection Data for Pullman Area Communication", April 1970.
- (27) Washington State Planning and Community Affairs Agency, "Population-Counties and Municipalities of the State of Washington", April 1968.
- (28) Washington State University, Office of University Development, "The Projected Continued Growth of Washington State University as it Relates to the Need for Private Housing", August 1969.
- (29) Washington State University, Office of University Development, "Enumeration and Estimates of Washington State University Enrollment" as revised April 1970.
- (30) Water Supply Act of 1958 (Title III of PL 85-500) as amended 1961.
- (31) Williams, R. E. et al, "Feasibility of Re-Use of Treated Wastewater for Irrigation, Fertilization and Groundwater Recharge in Idaho", Pamphlet 143, Idaho Bureau of Mines and Geology, October 1969.



**Stevens, Thompson & Runyan, Inc.**

*Engineers / Planners*

827 LA CASSIA DRIVE

BOISE, IDAHO 83705

TELEPHONE (208) 343-3609

Fifty Years  
1920-1970

Portland  
Seattle  
Boise  
Anchorage

B-100.001

January 27, 1970

Mayor ----  
-----  
-----

Dear Mayor:

Our firm has been retained by the Pullman-Moscow Water Resource Committee (P-MWRC) to perform a water study. The committee is composed of representatives from the City of Pullman, Washington State University, the City of Moscow and the University of Idaho. Their primary purpose is to investigate alternate methods of augmenting their domestic water supplies from a common source.

The requirements of the water study include contacting and maintaining liaison with all interested parties, particularly neighboring communities, which are contemplating expansion of their water system. Consequently, we would appreciate the completion and return of the enclosed questionnaire concerning the future planning of your community's water system. Use of the information provided will be limited to the P-MWRC Water Study and will not obligate your community in any manner.

If you desire more information concerning this project, please feel free to request the same from this office. Your early response will be most appreciated.

Very truly yours,

STEVENS, THOMPSON & RUNYAN, INC.

By: Richard O. Day, P. E.  
Resident Manager

ROD:plk

cc: Portland  
Seattle

ESVELT & SAXTON  
CONSULTING ENGINEERS  
321 SYMONS BUILDING • SPOKANE, WASHINGTON 99204



JOHN P. ESVELT • W. W. SAXTON  
JOHN S. TUNISON, ASSOCIATE  
TELEPHONE (509) 624-9161

January 30, 1970  
E/S File 95-C

Mr. Richard O. Day, P.E.  
Stevens, Thompson & Runyan, Inc.  
827 La Cassia Drive  
Boise, Idaho 83705

Subject: Pullman - Moscow Water Study

Dear Mr. Day,

The City of Colfax has asked us to respond to your questionnaire regarding their domestic supply and potential water use.

Nearly three years ago we prepared a comprehensive engineering report covering every aspect of the City's domestic water supply and distribution system. Many recommendations were made to improve the overall supply and distribution picture and a major construction project was completed in 1968 as a result of these recommendations.


The project, however, did not include increasing the high quality water supply which amounts to 2100 gpm from two deep water wells and one artesian well. We recommended that another 500 gpm well be investigated to provide Colfax with a new source of supply which will be needed within the next twenty years if their current rate of water usage continues.

Although there is no immediate need for additional water, there is reason to believe that the artesian supply can be substantially reduced following successive low runoff years as was experienced between 1916 - 1926. This does not hold true, however, for the deep-water wells which have not shown a measurable drawdown since their completions.

Reasonably anticipating that the aquifer presently being used holds an abundance of the same high quality water, Colfax will not need another source of supply until at least 2010 when the population could be 4500. If after this time, further wells in the area prove not feasible, the City will be most interested in considering a "common area" source.

I hope this has sufficiently answered your questions. If you have need for further information, please contact us.

Very truly yours,

  
Michael A. Kennedy

ESVELT & SAXTON

MAK/ch

cc: City of Colfax

P-MWRC QUESTIONNAIRE  
BY  
STR ENGINEERS/PLANNERS

Name of Community: City of Troy, Idaho

Does your community have any current plans, ideas or concepts concerning the expansion or replacement of your water supply? No

If so, please give a brief description of such plans, ideas or concepts:

We are just completing the expansion of our Mountain Reservoir which should take care of our requirements for next 10 to 15 years.

Do you think that your community should consider the possibility of using water provided by a source serving the Pullman-Moscow urban area (assuming that such a scheme was economically feasible)? Yes

If so, when might your community need the water? 10 to 15 years

Would you like to discuss this matter in more detail with a representative of our firm? We wish to cooperate.

Please provide any additional comments you wish: \_\_\_\_\_

By: /s/ Eldon T. Strom  
(Person answering questionnaire)

Mayor  
(Position)



P-MWRC QUESTIONNAIRE  
BY  
STR ENGINEERS/PLANNERS

Name of Community: Kendrick, Idaho

Does your community have any current plans, ideas or concepts concerning the expansion or replacement of your water supply? No

If so, please give a brief description of such plans, ideas or concepts:

Do you think that your community should consider the possibility of using water provided by a source serving the Pullman-Moscow urban area (assuming that such a scheme was economically feasible)? No

If so, when might your community need the water? \_\_\_\_\_

Would you like to discuss this matter in more detail with a representative of our firm? No

Please provide any additional comments you wish: \_\_\_\_\_

By: /s/ Robert Watts  
(Person answering questionnaire)

Mayor  
(Position)

P-MWRC QUESTIONNAIRE  
BY  
STR ENGINEERS/PLANNERS

Name of Community: Palouse

Does your community have any current plans, ideas or concepts concerning the expansion or replacement of your water supply? \_\_\_\_\_

If so, please give a brief description of such plans, ideas or concepts:

Our water meter count has increased from 350 to 400+ in two years. Our pumps were running at 100% capacity last summer. We are making plans to systematically replace the whole system a little at a time. We have 500,000 storage and are looking into building another storage tank. So, yes we are interested in more water. Per capita water consumption is up also.

Do you think that your community should consider the possibility of using water provided by a source serving the Pullman-Moscow urban area (assuming that such a scheme was economically feasible)? Yes

If so, when might your community need the water? 5 years

Would you like to discuss this matter in more detail with a representative of our firm? Yes

Please provide any additional comments you wish: \_\_\_\_\_

We cleaned out sand last year which increased our capacity somewhat. We also lowered the pump 20 feet. We have one drilled well plus an artesian well that we use in the summer.

By: /s/ Leo J. Schmidt  
(Person answering questionnaire)

Mayor  
(Position)

P.S. - Council meet 1st Tuesdays 7:30 PM

P-MWRC QUESTIONNAIRE  
BY  
STR ENGINEERS/PLANNERS

Name of Community: Uniontown, Washington

Does your community have any current plans, ideas or concepts concerning the expansion or replacement of your water supply? Not at this time

If so, please give a brief description of such plans, ideas or concepts:

Do you think that your community should consider the possibility of using water provided by a source serving the Pullman-Moscow urban area (assuming that such a scheme was economically feasible)? Not at this time

If so, when might your community need the water? \_\_\_\_\_

Would you like to discuss this matter in more detail with a representative of our firm? No

Please provide any additional comments you wish: \_\_\_\_\_

By: /s/ Maurice Money maker  
(Person answering questionnaire)

Mayor  
(Position)

P-MWRC QUESTIONNAIRE  
BY  
STR ENGINEERS/PLANNERS

Name of Community: Colton

Does your community have any current plans, ideas or concepts concerning the expansion or replacement of your water supply? No

If so, please give a brief description of such plans, ideas or concepts:

Do you think that your community should consider the possibility of using water provided by a source serving the Pullman-Moscow urban area (assuming that such a scheme was economically feasible)? No

If so, when might your community need the water? \_\_\_\_\_

Would you like to discuss this matter in more detail with a representative of our firm? Not at present

Please provide any additional comments you wish: \_\_\_\_\_

By: /s/ Delbert Meyer  
(Person answering questionnaire)

Councilman  
(Position)